

(1) OWNER: **STATE ENGINEER WASC**  
Name Albert Francois  
Address R2 The Dalles **002872**

(2) LOCATION OF WELL:  
County Wasco Owner's number, if any—  
1/4 Section 7 T. 2N R. 12E W.M.  
Bearing and distance from section or subdivision corner

TYPE OF WORK (check):  
Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):  
 Industrial  Municipal   
 Test Well  Other

(5) TYPE OF WELL:  
Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED: Threaded  Welded   
8" Diam. from 0 ft. to 272 ft. Gage 17 pd.  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated?  Yes  No  
Type of perforator used  
SIZE of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

SCREENS: Well screen installed  Yes  No  
Driller's Name  
Model No.  
Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

CONSTRUCTION:  
Gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Was a surface seal provided?  Yes  No To what depth? 272 ft.  
Material used in seal— drill muck  
Did any strata contain unusable water?  Yes  No  
Type of water? sulfur Depth of strata 375  
Method of sealing strata off casing & drill muck

(10) WATER LEVELS:  
Static level 197 ft. below land surface Date 3-12-60  
Artesian pressure lbs. per square inch Date

Log Accepted by:  
[Signed] Albert Francois Date March 31, 1960  
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Bert Clayton  
Yield app. 200 gal./min. with no ft. drawdown after 1 hrs.

" **OBSERVATION WELL** "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 60° Was a chemical analysis made?  Yes  No

(12) WELL LOG: Diameter of well 8 inches.  
Depth drilled 401 ft. Depth of completed well 401 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Brown soil	0	3
Grey sandstone	3	25
Red & blue boulders	25	57
Yellow joint clay	57	66
Grey sandstone, red & blue bld	66	90
Blue joint clay	90	115
Brown sandstone	115	165
Trinkle of water at 130 ft.		
Yellow sandy clay	165	185
Brown sandstone	185	215
Bluish grey sandy clay	215	221
Brown, black & red rock	221	229
Green clay & black porous rock	229	244
Black rock	244	260
Hard grey rock	260	329
Soft grey rock	329	330
Bluish grey rock	330	361
Grey rock	361	373
Black porous rock & Pyrite iron	373	394
Hard dark grey rock	394	401

Work started Aug. 1 1959. Completed March 12 1960

(13) PUMP:  
Manufacturer's Name Fairbanks-Morse  
Type: Submersible H.P. 30

Well Driller's Statement:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Bert Clayton  
(Person, firm, or corporation) (Type or print)  
Address 2313 E. 10th Street, The Dalles

Driller's well number  
[Signed] Bert Clayton  
(Well Driller)  
License No. 54 Date March 31, 1960