NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

bc

STATE ENGINEER, SALEM, OREGON 27310 TE EN (Please type or print) within 30 days from the date of well completion. SALEM Of (Do not write above this line) 002911.

			5.
State	Permit	No.	

(1) OWNER:	(10) LOCATION OF WELL:	
	County W2SCO Driller's well number	
Name Hugh Jamison Address Rt. 4 The Dalles, Ore. 97058	SW 14 NW 14 Section 10 T. 2N R. 12E	W.M.
NO.44 THE DATTER, OLS. ALOSE	Bearing and distance from section or subdivision corner	
(2) TYPE OF WORK (check):	Dearing and distance arone section of based about	
New Well ☐ Deepening ☒ Reconditioning ☐ Abandon ☐		
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	-
(3) TYPE OF WELL: (4) PROPOSED USE (check):	****	
	Depth at which water was first found	/ru
Cable Jetted 🗆 Domestic 🗀 industrial 🗀 Municipal-	Static level 108 ft. below land surface. Date 1/31	<u>/14</u>
Dug ☐ Bored ☐ Irrigation ☐ Test Well ☐ Other ☐	Artesian pressure lbs. per square inch. Date	
Threaded Welded	(12) WELL LOG: Diameter of well below casing	
" Diam. from ft. toft. Gage	1 FF	
" Diam, fromft. toft. Gage		ft.
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of mai and show thickness and nature of each stratum and aquifer pene	terials;
Diani. Holii	with at least one entry for each change of formation. Report each cho	ange in
PerforationS: Perforated? Yes No.	position of Static Water Level and indicate principal water-bearing	strata.
Type of perforator used	MATERIAL From To	swl
Size of perforations in. by in.	Basalt blue hard 285 299	112
perforations from ft. to ft.	Basalt blue very hard 299 318	
perforations fromft. toft.		110
perforations fromft. toft.	Basalt blue hard 334 345	
periorations from to to to		108
(7) SCREENS: Well screen installed? Yes No		
Manufacturer's Name		
Type Model No		
Diam Slot size Set from ft. to ft.		
Diam, Slot size Set from ft. to ft.		
(2) WELL TESTS. Drawdown is amount water level is		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? 📮 Yes 🗌 No If yes, by whom?		
Yield: 90 gal./min. with 60 ft. drawdown after 18 hrs.		
" " "	and the second of the second o	
n n n		
	- 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1,	
Bailer test gal./min. with ft. drawdown after hrs.	* * * * * * * * * * * * * * * * * * *	
Artesian flow g.p.m.		
Temperature of water 58 Depth artesian flow encountered ft.	Work started 1/20 1974 Completed 36 1/30	¹⁹ 74
(9) CONSTRUCTION:	Date well drilling machine moved off of well 1/30	19 7/4
•	Drilling Machine Operator's Certification:	
Well seal—Material used	This well was constructed under my direct superv	ision.
Well sealed from land surface toft.	Materials used and information reported above are true best knowledge and belief.	to my
Diameter of well bore to bottom of seal in. Diameter of well bore below seal in.	[Signed] Hugh R Commandate 2/2	1071.
Number of sacks of cement used in well seal sacks	(Drilling Machine Operator)	
Number of sacks of bentonite used in well sealsacks	Drilling Machine Operator's License No. Owner.	
Brand name of bentonite		
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:	
of waterlbs./100 gals.	This well was drilled under my jurisdiction and this repetrue to the best of my knowledge and belief.	port is
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.		
Did any strata contain unusable water? Yes No	Name (Person, firm or corporation) (Type or print))
Type of water? depth of strata	Address	
Method of sealing strata off	[Signed]	
Was well gravel packed? Yes No Size of gravel:	The state of the s	-
Gravel placed from ft. to ft.	Contractor's License No Date	. 19