NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report

within 30 days from the date of well completion.

## water well report water resources department E V E STATE OF OREGON A salem, oregon 97310 within 30 days from the

JAN2 7 1978 (Do not write above this line)

State Well No. 2NIZE-18ba

603028State Permit No. G-9795 (wall 2)

WATER RESOURCES DEPT.	· · · · · · · · · · · · · · · · · · ·
(1) OWNER: SALEM, OREGON	(10) LOCATION OF WELL:
Name Paul Brooks	County Wasco Driller's well number
Address Mosier, Oregon	NE 34 NW 34 Section 18 T. 2N R. 12E W.M.
	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	The second of second se
New Well Deepening Reconditioning Abandon	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	210
Rotary N Driven D Domestic Industrial Municipal	
Sante Li Setted Li	Static level 217 ft. below land surface. Date 17 Jan
Dug   Bored   Irrigation   Test Well   Other	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded □ Welded	(12) WELL LOG: Diameter of well below casing 8
8 "Diam from 0 ft. to 139 ft. Gage 250	7. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1.
" Diam. fromft. toft. Gage	
" Diam, from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,
PERFORATIONS: Perforated? [] Ves. VI No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
2 c. 10 1 c. 7 1 c.	
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	Soil 0 7
perforations from ft. to ft.	Sand 7 36
perforations from ft. to ft.	Sandstone tan 36 72 Cobles 72 78
perforations from ft. to ft.	
(7) SCREENS: Well screen installed?   Yes   No	Clay gray         78         102           Sandstone gray         102         123
Manufacturer's Name	
Type	Basalt gray WB 123 275
Diam. Slot size Set from ft. to ft.	Rock gray & green WB 275 390
Diam. Slot size Set from ft. to ft.	Basalt gray visic. WB 390 460 217
The state of the s	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? ☐ Yes ② No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	
S GOT MILL BLI LESC WILL TOUR	
drawdown at 460' "	A CONTRACTOR OF THE CONTRACTOR
Bailer test gal./min. with ft. drawdown after hrs.	The second of th
Artesian flow g.p.m.	1.77 - 2.27 - 2.41
perature of water Depth artesian flow encountered ft.	Work started 7 Jan 19 78 completed 17 Jan 19 78
9) CONSTRUCTION:	Date well drilling machine moved off of well 17 Jan 19 78
Wall and Material Bentonite	Taker
Well sealed from land surface to 18	Drilling Machine Operator's Certification:  This well was constructed under my direct supervision.
To seated from faile surface to	Materials used and information reported above are true to my
n. in.	best knowledge and belief.
Diameter of well bore below seal in.  Jumber of sacks of cement used in well seal sacks	[Signed] (Drilling Machine Operator) Date 23 Jan, 1978
Sacks of cement used in well sealsacks	Drilling Machine Operator's License No737
3 sacks	
	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is
Vas a drive shoe used?   Yes  No Plugs Size: location ft.	true to the best of my knowledge and belief.
oid any strata contain unusable water?   Yes X No	Name Richard J. Murray  (Person, firm or corporation) (Type or print)
11	Address 3.712 W 8th The Dalles, Oregon
tethod of searing strata off	[Signed] Cachical Market (Water Well Confractor)
Vas well gravel packed? ☐ Yes XNo Size of gravel:	(Water Well Contractor)
ravel placed from ft. to ft.	Contractor's License No. 606 Date 23 Jan , 1978