

RECEIVED

WVASSC

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

FEB 20 1962 WATER WELL REPORT

STATE ENGINEER STATE OF OREGON SALEM, OREGON (Please type or print)

003215

State Well No.

G-3961

State Permit No.

2N/12-36L(3)

(1) OWNER:

Name W. S. Nelson

Address 704 Federal Street The Dalles, Oregon

(2) LOCATION OF WELL:

County Wasco Driller's well number 1/4 1/4 Section 36 T. 2 N R. 12 E W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ] Irrigation [X] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 29 1/2 ft. Gage 279 8" Diam. from 0 ft. to 151 1/2 ft. Gage 188

(7) PERFORATIONS:

Perforated? [ ] Yes [X] No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed [ ] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal drill muck Depth of seal 29 1/2 ft. Was a packer used? no Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? [ ] Yes [X] No Depth Was a drive shoe used? [X] Yes [ ] No Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [ ] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 43 1/2 ft. below land surface Date 1/31/62 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 60 gal./min. with 25 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [ ] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 8" Depth drilled 320 ft. Depth of completed well 320 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Soil, brown, sandy, round rocks; Boulders; Sandstone, light grey; Sandstone, brown; Clay, bentonite; Sandstone, light greyish brown; Sandstone, redish brown; Sandstone, brown, rocky; Sand, light brown; Clay, light brown; Clay, white; Sandstone, brown; Sandstone, brown & rocky; Clay, white; Sandstone, brown.

Work started 12/27 1961 Completed 1/30 1962 Date well drilling machine moved off of well 2/1 1962

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Bert Clayton & Son (Person, firm or corporation) (Type or print)

Address 2313 E. 10th St., The Dalles, Ore.

Drilling Machine Operator's License No. 298

[Signed] Bert Clayton (Water Well Contractor)

Contractor's License No. 54 Date 2-19, 1962