

WATER WELL REPORT  
STATE OF OREGON

WASC  
009335

RECEIVED

State Well No. 2W/14E-25d  
State Permit No.

PLEASE TYPE or PRINT IN JAN 3 1 1984

WATER RESOURCES DEPT.

(1) OWNER:

Name Max Kaseberg  
Address 4980 Fifteen Mile Road  
City The Dalles OR 97058 State

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air  Driven   
Rotary Mud  Dug   
 Bored

(4) PROPOSED USE (check):

Domestic  Industrial   
Irrigation  Test Well   
Thermal:  Withdrawal  ReInjection

(5) CASING INSTALLED:

Steel  Plastic   
Threaded  Welded   
8" Diam. from +1 ft. to 32 ft. Gauge .250  
" Diam. from ft. to ft. Gauge

LINER INSTALLED:

6" Diam. from +1 ft. to 41 ft. Gauge .250

(6) PERFORATIONS:

Perforated?  Yes  No

Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot Size Set from ft. to ft.  
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level.

Was a pump test made?  Yes  No If yes, by whom?  
d: gal./min. with ft. drawdown after hrs.  
Air test 30 gal./min. with drill stem at 100 ft. 1 hrs.  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m.  
Temperature of water 60° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes  No

Well seal—Material used cement groute  
Well sealed from land surface to 32 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 67 sacks  
How was cement grout placed? pressure grouted with pump  
Was pump installed? no Type HP Depth ft.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of Water? creek depth of strata 35 ft.  
Method of sealing strata off cased off with 6" casing  
Was well gravel packed?  Yes  No Size of gravel: ft.  
Gravel placed from ft. to ft.

(10) LOCAL WELL:

County Wasco Driller's well number  
NE ¼ SE ¼ Section 25 T. 2 N R. 14 E. W.M.  
Tax Lot # Lot Blk Subdivision  
Address at well location: same

(11) WATER LEVEL: Completed well.

Depth at which water was first found 35 ft.  
Static level 18 ft. below land surface. Date 1-12-84  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 120 ft. Depth of completed well 121 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil, brown	0	3	
Clay, brown	3	21	
Clay, brown rocky	21	32	
Rock, grey, broken	32	37	
Rock, grey, hard	37	70	
Rock, broken decomposed	70	107	18
Rock, grey, hard	107	120	18

Work started Dec. 7 19 83 Completed Jan. 12 19 84  
Date well drilling machine moved off of well January 12, 19 84

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Date, 19

Bonded Water Well Constructor Certification:

Bond 9497437 Issued by: Fidelity & Deposit Co.  
(number) of Maryland

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Gilbert Clayton Well Drilling  
(Person, firm or corporation) (Type or print)

Address 1951 Lambert St, The Dalles OR 97058

[Signed] Gilbert Clayton  
Water Well Constructor

Date January 27, 19 84

NOTICE TO WATER WELL CONSTRUCTOR

The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date of well completion.

SP\*45292-690