

NOTICE TO WATER WELL CONTRACTOR

WASC

The original and first copy of this report are to be filed with the

003437

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 1/13-26ddlb

State Permit No. well #1

(1) OWNER:

Name Roy P. BARNET
Address 219 E. 4th The Dalles Oregon

(2) TYPE OF WORK (check):

New Well X Deepening X Reconditioning [ ] Abandon [ ]

(3) TYPE OF WELL:

Rotary X Driven [ ]
Cable [ ] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well X Other [ ]

(11) LOCATION OF WELL:

County WASC0 Driller's well number
1/4 1/4 Section 26 T. 15 R. 13 E. W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6" x 8"
Depth drilled 336 ft. Depth of completed well 411 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Contains handwritten entries for various geological layers like 'Art Shale', 'Hard Grey Basalt', 'Med Brown Basalt', etc.

CASING INSTALLED:

8" Diam. from 7.1 ft. to 19 ft. Gage 1/4
" Diam. from ... ft. to ... ft. Gage 1/4

PERFORATIONS:

Perforated? [ ] Yes [X] No

Table with columns: Size of perforations, in. by, in., ft. to, ft. Contains multiple rows of perforation data.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level over ft. below land surface Date
an pressure 16 lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [ ] Yes [X] No If yes, by whom?
gal./min. with ft. drawdown after hrs.
air lift
Bailer test 180 gal./min. with ft. drawdown after hrs.
Artesian flow 80 g.p.m. Date 2-1-68
Temperature of water 56 Was a chemical analysis made? [ ] Yes [X] No

(10) CONSTRUCTION:

Well seal—Material used cement
Depth of seal 19 ft
Diameter of well bore to bottom of seal 11 in.
Were any loose strata cemented off? [ ] Yes [X] No Depth
Was a drive shoe used? [ ] Yes [X] No
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

Work started 12/6 1967 Completed 2/17 1968
Date well drilling machine moved off of well 2/19 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Dick Atkins Date 2/19 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 249

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Dick Atkins WELL DRILLING
(Person, firm or corporation) (Type or print)

Address P.O. Box 264 Prineville OR

[Signed] Dick Atkins
(Water Well Contractor)

Contractor's License No. 260 Date 2/19 1968