

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
WATER WELL REPORT WASC
 AUG 26 1968 STATE OF OREGON
 STATE ENGINEER SALEM OREGON

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

STATE ENGINEER SALEM OREGON

003440

State Well No. 1/13-26

State Permit No.

(1) OWNER:

Name Roy P Barnett
 Address 1219 E 9th The Dalles Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dig Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
 8" Diam. from 0 ft. to 75 ft. Gage 277
 10" Diam. from 71 ft. to 8 ft. Gage 250

PERFORATIONS:

Perforated? Yes No

Type of perforator used —
 Size of perforations in. by in.
 perforations from ft. to ft.
~~perforations from ft. to ft.~~
~~perforations from ft. to ft.~~
~~perforations from ft. to ft.~~

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name —
 Type — Model No. —
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level artesian ft. below land surface Date 8/15/68
 Artesian pressure 12 # lbs. per square inch Date 8/17/68

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
 i: gal./min. with ft. drawdown after hrs.
 " air lift " " "
 " 500 p.m. " " "
 Bailer test 500 gal./min. with ft. drawdown after hrs.
 Artesian flow 180 g.p.m. Date 8/15/68
 Temperature of water 48 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Cement GROUT
 Depth of seal 75 ft.
 Diameter of well bore to bottom of seal 10 in.
 Were any loose strata cemented off? Yes No Depth —
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? — depth of strata —
 Method of sealing strata off —
 Was well gravel packed? Yes No Size of gravel: —
 Gravel placed from — ft. to — ft.

(11) LOCATION OF WELL:

County WASCO Driller's well number —
 1/4 Section 26 T. 15 R. 13E W.M.
 Bearing and distance from section or subdivision corner —

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 300 ft. Depth of completed well 250 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Hard grey Basalt	3	75	artesian 180 gal flow
Reamed to 75 ft set 75 ft of 8 inch casing & cemented in			
Barnett			
Well No #2			

Work started 8/5 1968 Completed 8/15 1968
 Date well drilling machine moved off of well 8/15 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Dick Akins Date 8/17, 1968
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 249

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME DICK AKINS WELL DRILLING
 (Person in charge of operation) (Type or print)

Address PO BOX 234 PRINEVILLE, OREGON

[Signed] Dick Akins
 (Water Well Contractor)

Contractor's License No. 260 Date 8/17, 1968