WATER WELL REPORT' STATE OF OREGON

WASE 003449

RECEIVED

State v

State Well No. 15/13E-32 dd

APR 9 1981

WATER RESOURCES DEPT SALEM. OREGON

(1) OWNER:	(10) LOCATION OF WELL:	
Name Paul Schanno	County Wasco Driller's well number	. ^{***}
Address Route 3, Box 23	SE 4 SE 4 Section 32 T. 1 S R. 13 E. W.	М.
city The Dalles, Oregon State 97058	Tax Lot # Lot Blk Subdivision	
(2) TYPE OF WORK (check):	Address at well location: Route 1	
ar-	Dufur, Oregon 97021	
New Well. Deepening □ Reconditioning □ Abandon □ If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
	Depth at which water was first found 370	ft.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level flowing ft. below land surface. Date 4-1-8	31
Rotary Air A Driven Domestic Industrial Municipal Rotary Mud Dug Irrigation Z Test Well Other	Artesian pressure 10 lbs. per square inch. Date $4-1$	
Bored	(12) WELL LOG: Diameter of well below casing 811	-
(5) CASING INSTALLED: Steel Plastic	Depth drilled 447 ft. Depth of completed well 447	ft.
(5) CASING INSTALLED: Steel Plastic Threaded Welded W	Formation: Describe color, texture, grain size and structure of materials; and sh	
10 "Diam from	thickness and nature of each stratum and aquifer penetrated, with at least one en for each change of formation. Report each change in position of Static Water Le	
"Diam. from	and indicate principal water-bearing strata.	
INER INSTALLED:	MATERIAL From To SWL	_
8 "Diam from 0 ft to 148 ft Gauge . 188	Soil, black 0 10	
(6) PERFORATIONS: Perforated? ☐ Yes ※ No	Clav. brown rocky 10 22	
Type of perforator used	Gravel, large 22 27	
Size of perforations in. by in.	Sandstone; brown 27 47	
perforations fromft. toft.	Rock, decomposed 47 112	
perforations fromft. toft.	Rock, broken 112 132	
perforations from ft. to ft.	Rock, grey 132 202	
(7) SCREENS: Well screen installed? Yes No	Rock, grey & brown 202 222	
Manufacturer's Name	Rock, black 222 309	
Type Model No	Rock, greenish grey 309 326	
Diam. Slot Size Set from ft. to ft.	Rock, grey hard 326 336 Rock, greenish grey 336 370	
Diam. Slot Size Set from ft. to ft.	Rock, porous brown 370 380 flor	— พาก
Drawdown is amount water level is lowered	Rock, porous black/quartz 380 386	14 .4. 2.
below static level	Rock, porous black 386 410	-
a pump test made? Yes No If yes, by whom?	Rock, grey hard 410 440 11	
A.d: gal/min. with ft. drawdown after hrs.	Rock, conglomerate 440 445 flo	wi.
The state of the s	Rock, grey hard 445 447 "	
Air test 1,100 gal/min. with drill stem at 40 ft. 1 hrs.		
Bailer test gal/min. with ft. drawdown after hrs.	Well capped/flanged plate	
an flow 175 g.p.m. 1 Superature of water 54° Depth artesian flow encountered 370 ft.	_ r gave varve & pressure gauge	≂-
	Work started March 10 1981 Completed April 1 19	
(9) CONSTRUCTION: Special standards: Yes X No Well seal—Material used Cement grout	Date well drilling machine moved off of well April 1 19	<u>2T</u>
7 11 O 20 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	Drilling Machine Operator's Certification:	
Well sealed from land surface to	This well was constructed under my direct supervision. Materials us and information reported above are true to my best knowledge and belie	ed
Diameter of well bore to bottom of seal	Signed Dellers Control Date 4-2 10	
Number of sacks of cement used in well seal	(Drilling Machine Operator)	
How was cement grout placed?	Drilling Machine Operator's License No. 129	··_
pressure grouted with pump	Water Well Contractor's Certification:	
	This well was drilled under my jurisdiction and this report is true	to
Was pump installed?	the best of my knowledge and belief. NamGilbert Clayton Well Drilling	
Was a drive shoe used? M Yes □ No Plugs Size: location ft.		 - 0
Did any strata contain unusable water?	Address 1, Box 61-A, The Dalles, (Type 1970)	 50.
Type of Water? depth of strata	[Signed] Sylver College	
Method of sealing strata off	(Water Well Contractor)	 Ят
Was well gravel packed? ☐ Yes to No Size of gravel:	Contractor's License No. 569 Date April 2 ,19	81
Gravel placed from		