

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
WATER WELL REPORT WASC
 APR 28 1970
 STATE ENGINEER
 SALEM, OREGON

State Well No. 4/11-136a
 State Permit No. 003545

(1) OWNER:

Name W.D. Cody
 Address Box 67, Wamie, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
 " Diam. from 0 ft. to 21 ft. Gage .250
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No
 Type of perforator used _____
 Size of perforations in. by in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 410 ft. below land surface Date 4/1/70
 Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: 60 gal./min. with _____ ft. drawdown after _____ hrs.
Air Test " " " "
 " " " "
 " " " "
 Bailor test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water 56 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Cement Grout
 Depth of seal 21' ft.
 Diameter of well bore to bottom of seal 12 1/4 in.
 Were any loose strata cemented off? Yes No Depth 0-5
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Wasco Driller's well number _____
NE 1/4 NW 1/4 Section 13 T. 4S R. 11 E W.M.
 Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 8
 Depth drilled 560 ft. Depth of completed well 560 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Boulders, Large, Soil, Brw	0	5	
Basalt, Brown	5	22	
Basalt, Gray, Hard	22	27	
Basalt, Brown	27	40	
Cemented Gravel, Coarse	40	65	
Basalt, Black	65	72	
Gravel, Coarse	72	95	
Basalt, Hard, Black			
Gravel, Fine to Coarse	95	135	
Basalt, Hard, Black	135	215	
Basalt, Gray, Hard	215	225	
Basalt, Broken, Black	225	240	
Gravel, Clay, Red	240	295	
Basalt, Gray, Hard	295	335	
Claystone, Gray	335	385	
Basalt, Gray, Hrad	385	420	
Basalt Gray	420	533	
Broken Basalt, Brw, Red	533	552	Water
Basalt, Gray Hard	552	560	

Work started March 25 1970 Completed April 1 1970
 Date well drilling machine moved off of well April 2 1970

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Don Parry JK Date April 2, 70
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 640

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME PROJECT: Corporation
 (Person, firm or corporation) (Type or print)

Address One South Second, Walla Walla, Wn.

[Signed] Gary Hiesey JK
 (Water Well Contractor)

Contractor's License No. 527 Date April 27, 1970.