

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

WATER WELL REPORT

RECEIVED

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

STATE OF OREGON  
(Please type or print)

JUN 24 1977  
Write above this line)

003579

State Well No. 45/12E-10dd

State Permit No.

(1) OWNER:

Name PAUL TREANOR  
Address P.O. Box WAMIC, ORE

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Cable  Driven  Jetted  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other

(5) CASING INSTALLED:

Threaded  Welded   
8" Diam. from 0 ft. to 19 ft. Gage 250  
6" Diam. from 0 ft. to 300 ft. Gage 156

(6) PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used

Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Flow: gal./min. with ft. drawdown after hrs.  
Bailer test 60 gal./min. with 0 ft. drawdown after 2 hrs.  
Artesian flow g.p.m.  
Temperature of water 54 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT  
Well sealed from land surface to 19 ft.  
Diameter of well bore to bottom of seal 12 in.  
Diameter of well bore below seal 8 in.  
Number of sacks of cement used in well seal 5 sacks  
Number of sacks of bentonite used in well seal sacks  
Brand name of bentonite  
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County WASCO Driller's well number  
SE 1/4 J5 1/4 Section 10 T. 4 R. 12 E W.M.  
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 296 ft.  
Static level 201 ft. below land surface. Date 4/1/77  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8  
Depth drilled 300 ft. Depth of completed well 300 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	5	
BOLD CLAY	5	170	
BASALT	170	253	
SANDSTONE RED	253	265	
SANDSTONE BROWN	265	276	
WATER BEARING SAND			
WITH TRACES OF CLAY	276	300	

Work started 3/31/76 19 Completed 8/4/76 19  
Date well drilling machine moved off of well 4/4/76 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] R.M. Muege Date 4/1/77  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 487

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name McGee & Sons Well Drilling Co.  
(Person, firm or corporation) (Type or print)

Address 67360 Fry Road Bend

[Signed] J.B. McGee  
(Water Well Contractor)

Contractor's License No. 544 Date 4-10, 1977