NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report

WATER RESOURCES DEPARTMENT SALEM, OREGON OFFICE OF STREET SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON State Well No

(Please type or print) (Do not write above this line)

State Permit No.

(1) OWNER:	(10) LOCATION OF WELL:
Name THOMAS MORELLI	County WASCO Driller's well number 78-06
Address RT / Box /26	NE 14 Section 27 T. 45 R. /3E. W.M.
MAUPIN OR. 97037	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well Deepening Reconditioning Abandon	6 L
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 4/2 ft.
Rotary Driven Domestic Industrial Municipal Cable Jetted	Static level 280 ft. below land surface. Date 4/6/7
Dug Bored IIrrigation Test Well Other	Artesian pressure Ibs. per square inch. Date
(5) CASING INSTALLED: Threaded Welded X O "Diam from t t to 60 ft. Gage 250 "Diam from ft to ft. Gage	(12) WELL LOG: Diameter of well below casing Depth drilled ALO ft. Depth of completed well AGO ft. Formation: Describe color, texture, grain size and structure of materials;
ft. toft. Gage	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in
(6) PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	CLAY + GRAVEL
perforations from ft. to ft.	SAUDSTODE GRAY ME S. MARCO 8 22
perforations from ft. to ft.	BASALT BROWN SYC 22 51
perforations from ft. to ft.	LAUR BANG HARD 107 1/6/
(7) SCREENS: Well screen installed? Yes No	RASALT BRU. HARD 161 236
Manufacturer's Name	SAINSTON BROWN MED HAL 236 331 280
Type Model No	GASALT BROWN HALL , 331 350
Diam Slot size Set from ft. to ft.	LAVA BLX ARED MED HART 350 4/2
Diam. Slot size Set from ft. to ft.	IST WATER 4/2
(8) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? Yes \(\) No If yes, by whom?	FLOWING SAND (LONE 427 900)
Yield: 400 gal./min. with 10 ft. drawdown after 5/2 hrs.	
, n n n n	No.
,, ,, ,, ,, ,, ,, ,, ,, ,, ,, ,, ,, ,,	
Bailer test gal./min. with ft. drawdown after hrs.	a
Artesian flow g.p.m.	
emperature of water 5 4 Depth artesian flow encounteredft.	Work started # 19 78 Completed # 1/3 1976
(9) CONSTRUCTION:	Date well drilling machine moved off of well 4/13 19/1
Well seal-Material used CEMENT	Drilling Machine Operator's Certification:
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of sealin.	best knowledge and belief
Diameter of well bore below sealin.	[Signed] Date 4/27, 1978
Number of sacks of cement used in well sealsacks	Drilling Machine Operator's License No
How was cement grout placed?	Dining Machine Operators Diceine 100
	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is
Was a drive shoe used? XYes □ No Plugs Size: location ft.	true to the best of my knowledge and belief.
Did any strata contain unusable water? Yes No	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address RO- Dex 571 LAKE DSIJEGA, DL 9703
Method of sealing strata off	A Com of
Was well gravel packed? Yes No Size of gravel:	[Signed] (Water Well Contractor)
The man graver parison of the parison of gravers and annual contraction	177 4/27 1078