NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line) 003724

WMASSC

State Well No. 6S/12E-24bb
State Permit No.

RECEIVED
JUL - 9 1979
WATER RESOURCES DEPT
SALEM, OREGON

(1) OWNER:
Name Harold E. Carter
Address RT. 1 Box 27, Maupin, OR. 97037

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [X] Driven [ ]
Cable [ ] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(5) CASING INSTALLED: Threaded [ ] Welded XX
10" Diam. from +1 ft. to 19 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? [ ] Yes [X] No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? [ ] Yes XX No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [ ] No If yes, by whom? Driller
Yield: 200 gal./min. with 12 ft. drawdown after 3 hrs.
" " " "
" Air Lift " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 59 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement Grout
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 23 sacks
How was cement grout placed?
Pumped
Was a drive shoe used? [ ] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County WASCO Driller's well number 79-14
NW ¼ NW ¼ Section 24 T. 5S R. 12 E. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 317 ft.
Static level 517 ft. below land surface. Date 6/5/79
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 8"
Depth drilled 700 ft. Depth of completed well 700 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Clay brown	0	3	
Basalt brown hard	3	47	
Cinder red med	47	53	
Basalt grey Hard	53	99	
Lava W/Cinder red hard	99	114	
Basalt brown	114	127	
Cinder red med.	127	132	
Basalt brown hard	132	147	
Cinder red med.	147	154	
Basalt brown hard	154	170	
Cinder red med.	170	174	
Basalt brown hard	174	191	
Basalt grey hard	191	222	
Basalt brown hard	222	236	
Cinder red soft	236	240	
Basalt brown hard	240	261	
Conglomerate med.	261	273	
Basalt grey Fractures WB.hard	273	417	317
Cont.			

Work started 5/22 19 79 Completed 6/6 19 79
Date well drilling machine moved off of well 6/7 19 79

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] William Lee (Drilling Machine Operator) Date 7/5, 1979
Drilling Machine Operator's License No. 700

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Marinelli Drilling Company (Person, firm or corporation) (Type or print)
Address P.O. Box 571, Lake Oswego, OR. 97034
[Signed] (Water Well Contractor)
Contractor's License No. 672 Date 7/5, 1979

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line) 003725

State Well No. 5S/12E-24bb
State Permit No.

(1) OWNER:
Name Harold E. Carter PAGE 2
Address Rt. Box 27, Maupin, OR. 97037

(2) TYPE OF WORK (check):
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:
Threaded ☐ Welded ☐
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? ☐ Yes ☐ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☐ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used
Well sealed from land surface to ft.
Diameter of well bore to bottom of seal in.
Diameter of well bore below seal in.
Number of sacks of cement used in well seal sacks
How was cement grout placed?
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County WASCO Driller's well number 79-14
NW ¼ NW ¼ Section 24 T. 5 S R. 12 E. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found ft.
Static level ft. below land surface. Date
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing
Depth drilled ft. Depth of completed well ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Cont. Page 2			
Clay brown soft	417	422	
Basalt brown hard	422	563	
Sandstone brown WB med	563	633	
Basalt brown hard	633	640	
Sandstone brown med.	640	700	

RECEIVED
JUL - 9 1979
WATER RESOURCES DEPT
SALEM, OREGON

Work started 19 Completed 19
Date well drilling machine moved off of well 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] (Drilling Machine Operator) Date , 19
Drilling Machine Operator's License No.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name (Person, firm or corporation) (Type or print)
Address
[Signed] (Water Well Contractor)
Contractor's License No. Date , 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119