

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date of well completion.

**WASCO WATER WELL REPORT RECEIVED**  
STATE OF OREGON  
MAR 21 1978  
003737  
(Do not write above this line)

State Well No. 55/12E-360C  
State Permit No. \_\_\_\_\_

**(1) OWNER:**

Name Paul Lewis  
Address Rt 1, Box 33 MAUPIS, OREG

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Cable  Dug   
Driven  Jetted  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
5" Diam. from 0 ft. to 20 ft. Gage 250"  
6" Diam. from 0 ft. to 400 ft. Gage 156"  
" Diam. from " ft. to " ft. Gage "

**(6) PERFORATIONS:**

Perforated?  Yes  No.  
Type of perforator used TORCH  
Size of perforations 1/4 in. by 8 in.  
93 perforations from 300 ft. to 400 ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " "  
" " " " "  
Bailer test 200 gal./min. with 0 ft. drawdown after 2 hrs.  
Artesian flow g.p.m. \_\_\_\_\_  
Temperature of water 54 Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used CEMENT  
Well sealed from land surface to 20 ft.  
Diameter of well bore to bottom of seal 12 in.  
Diameter of well bore below seal 8 in.  
Number of sacks of cement used in well seal 10 sacks  
How was cement grout placed? \_\_\_\_\_  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:**

County WASCO Driller's well number \_\_\_\_\_  
S10 1/4 NE 1/4 Section 36 T. 5 R. 12E W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 294 ft.  
Static level 160 ft. below land surface. Date \_\_\_\_\_  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 8  
Depth drilled 405 ft. Depth of completed well 400 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
OVER BURDEN	0	10	
BROWN SAND STONE	10	140	
CLAY & SAND STONE	140	290	
SAND & GRAVEL WATER BEARING	290	294	
BASALT	294	384	
WATER BEARING			
SAND & GRAVEL	384	400	
BASALT	400	405	

Work started 10/14/77 19 \_\_\_\_\_ Completed 10/25/77 19 \_\_\_\_\_  
Date well drilling machine moved off of well 10/25/77 19 \_\_\_\_\_

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] [Signature] Date 10/11/77, 19 \_\_\_\_\_  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 487

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Mc Coy & Sons Well Drilling Co  
(Person, firm or corporation) (Type or print)

Address 67360 Flypear Rd. Board

[Signed] [Signature]  
(Water Well Contractor)

Contractor's License No. 544 Date 10/31, 19 77