

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy of this report are to be filed with the
 WATER RESOURCES DEPARTMENT,
 SALEM, OREGON 97310
 within 30 days from the date
 of well completion.

WATER WELL REPORT
STATE OF OREGON
 (Please type or print)
 (Do not write above this line)

State Well No. 75/15E-18db
 State Permit No. _____

(1) OWNER:
 Name E. W. SWAN
 Address STAR ROUTE BOX 3 MADRAS ORE. 97037

(2) TYPE OF WORK (check):
 New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
 Dug Driven Domestic Industrial Municipal
 Jetted Irrigation Test Well Other
 Bored

(5) CASING INSTALLED: Threaded Welded
10 " Diam. from 0 ft. to 21 ft. Gage 257
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS: Perforated? Yes No.
 Type of perforator used _____
 Size of perforations _____ in. by _____ in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(7) SCREENS: Well screen installed? Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
 Is a pump test made? Yes No If yes, by whom? FRED ASHLEY
 Yield: 580 gal./min. with 70 ft. drawdown after 5 hrs.
 " " " " " "
 " " " " " "
 _____ test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m.
 Temperature of water 58 ° Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:
 Well seal—Material used CEMENT
 Well sealed from land surface to 19 ft.
 Diameter of well bore to bottom of seal 16 in.
 Diameter of well bore below seal 10 in.
 Number of sacks of cement used in well seal 22 sacks
 How was cement grout placed? GROUT PUMP

 Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:
 County WASCO Driller's well number _____
NW 1/4 S.E 1/4 Section 18 T. 75 R. 15 E W.M.
 Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.
 Depth at which water was first found 10.3 ft.
 Static level 119 ft. below land surface. Date JULY 21, 80
 Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: Diameter of well below casing 10 in.
 Depth drilled 207 ft. Depth of completed well 207 ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SANDY SOIL	0	2 1/2	
BROKEN BLACK BASALT	2 1/2	6	
BLACK BASALT	6	103	
LAVA CHUNKS	103	122	
CONGLOMERATE	122	170	
RYHOLITE YELLOW	170	174	
LAVA	174	190	
BLACK BASALT	190	207	

RECEIVED

AUG 13 1980

WATER RESOURCES DEPT
 SALEM, OREGON

Work started MAY 12 1980 Completed JULY 21 1980
 Date well drilling machine moved off of well JULY 22 1980

Drilling Machine Operator's Certification:
 This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
 [Signed] Lawrence Kowaleski Date Aug. 10, 1980
 (Drilling Machine Operator)
 Drilling Machine Operator's License No. 1

Water Well Contractor's Certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 Name LAWRENCE KOWALESKI
 (Person, firm or corporation) (Type or print)
 Address 741-4th MADRAS ORE
 [Signed] Lawrence Kowaleski
 (Water Well Contractor)
 Contractor's License No. 209 Date Aug 10, 1980