STATE OF OREGON	WELL I.D. LABEL# L 151238	
WATER SUPPLY WELL REPORT	START CARD # 1072421	
	ORIGINAL LOG#	
(as required by ORS 537.545 & 537.765 and OAR 690-205-0210) (1) LAND OWNER Owner Well I.D. RW-1		
(1) LAND OWNER Owner Well I.D. RW-1 First Name Last Name	─ WASC 5294	
First Name Last Name	(9) LOCATION OF WELL (legal description)	
Company MORAINE INDUSTRIES LLC	County WASCO Twp 2 N N/S Range 13 E E/W WM	
Address 2650 RIVER ROAD	Sec 33 NW 1/4 of the NW 1/4 Tax Lot 200	
City The Dalles State OR Zip 97058	Toy Man Number	
(2) TYPE OF WORK New Well Deepening Conversion	Tax Map Number Lot Lat " or 45.618936 DMS or DD Long " or -121.20804 DMS or DD	
Alteration (complete 2a & 10) Abandonment(complete 5a)	Lat OF 43.018930 DIVIS OF DD	
(2a) PRE-ALTERATION	Long or121.20804 DMS or DD	
Dia + From To Gauge Stl Plstc Wld Thrd	Street address of well Nearest address	
Casing:	2650 RIVER ROAD, THE DALLES, OR 97058	
Material From To Amt sacks/lbs	2030 KIVER ROAD, THE DALLES, OR 77030	
Seal:		
(3) DRILL METHOD	(10) STATIC WATER LEVEL	
X Rotary Air Rotary Mud Cable Auger Cable Mud	Date SWL(psi) + SWL(ft)	
Reverse Rotary Other	Existing Well / Pre-Alteration	
	Completed Well 03-13-2024 74	
(4) PROPOSED USE Domestic Irrigation Community	Flowing Artesian? Dry Hole?	
X Industrial/ Commercial Livestock Dewatering	WATER BEARING ZONES Depth water was first found	
Thermal Injection Other		
	2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	
(5) BORE HOLE CONSTRUCTION Special Standard (Attach copy	y) 01-11-2024 4.5 18 25 4.5	
Depth of Completed Well 320 ft.	01-19-2024 70 210 1,000 76.7	
BORE HOLE SEAL sacks.		
Dia From To Material From To Amt lbs	0130 2021 200 33000 7,011	
24 0 18.72 Cement 0 18.72 34 S		
Calculated 16.43		
20 18.72 210 Cement 0 210 338 S	(4) WELL LOC	
15 210 320 Calculated 151	(11) WELL LOG Ground Elevation	
How was seal placed: Method A B X C D E	Material From To	
Other	See Attached Formation Log	
Backfill placed from ft. to ft. Material		
Filter pack from ft. to ft. Material Size		
Seal Placement Begin Date 2024-01-26 Begin Time 12 00		
(5a) ABANDONMENT USING UNHYDRATED BENTONITE		
Proposed Amount Pounds Actual Amount Pounds		
(6) CASING/LINER Casing Liner Dia + From To Gauge Stl Plstc Wld Thrd		
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$		
12.75 315 320 .375 • X		
Shoe Inside Outside Other Location of shoe(s) 210		
(7) PERFORATIONS/SCREENS		
Perforations Method	Construction	
Screens Type Cont Wire Wrap Material 304 SS	Begin Date 01-08-2024 Begin Time 07 00 End Date 03-21-2024	
Perf/S Casing/ Screen Scrn/slot Slot # of Tele/	(unbonded) Water Well Constructor Certification	
creen Liner Dia From To width length slots pipe size		
Screen Liner 12.75 210 315 130 12.75	I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well	
	construction standards. Materials used and information reported above are true to	
	the best of my knowledge and belief.	
	License Number 2091 Date 4/11/24	
(8) WELL TESTS: Minimum testing time is 1 hour	a: 1 (1) (N	
Pump	Signed	
	(bonded) Water Well Constructor Certification	
Yield gal/min Drawdown Drill stem/Pump depth Duration (hr) 1.854 44.5 180 30		
1,634 44.3 160 30	I accept responsibility for the construction, deepening, alteration, or abandonmen	
	work performed on this well during the construction dates reported above. All work	
COLW + C 1 /	performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief	
Temperature 63 °F Lab analysis X Yes By GSI Water Solutions	construction standards. This report is true to the best of my knowledge and belief.	
Water quality concerns? Yes (describe below) TDS amount 210 mg/L	License Number 1523 Date 4/11/24	
From To Description Amount Units	01 -	
	Signed	
	Contact Info (optional)	

WELL I.D. LABEL# L 151238



12305 NE 56th Street Vancouver, WA 98682

Well Name: RW-1

Start Card/Permit #: 1072421

Label #: L151238

Label #: L151238		
	From:	To:
Backfill/gravel	0	2
Dark brown clay/top soil with organics	2	16
Byron interbed	16	18
Basalt dark gray	18	19.5
Basalt dark gray	19.5	40
Grey medium basalt	40	70
Grey med basalt w/ bits of blue clay mixed in	70	80
Green/grey med basalt w/ bits of blue clay mixed in	80	90
Grey med basalt w/ bits of blue clay mixed in	90	180
Fractured basalt with large chunks of blue clay, some brown material	180	198
Black med/soft basalt competent water bearing	198	210
Basalt dark grey med	210	250
Basalt grey to black weathering and abundant vesicles	250	260
Basalt grey to black minor weathering and vesicles	260	290
Basalt grey very minor weathering and vesicles	290	320
	+	
	+	
	+	

STATE OF OREGON WELL LOCATION MAP

Oregon Water Resources Department

725 Summer St NE, Salem OR 97301 (503)986-0900



This map is supplemental to the WATER SUPPLY WELL REPORT

LOCATION OF WELL

Latitude: 45.61893600 Datum: WGS84

Longitude: -121.20804000

Township/Range/Section/Quarter-Quarter Section:

WM2.00N13.00E33NWNW

Address of Well:

2650 RIVER ROAD, THE DALLES, OR 97058

Startcard: 1072421

Printed: April 11, 2024

DISCLAIMER: This map is intended to represent the approximate location the well. It is not intended to be construed as survey accurate in any manner.

Provided by well constructor

