

New exempt use wells must be submitted with a map and recording fee.

| |
|---|
| As to special standards, well was in 10' pit. Pulled pump and ran 693' of grout pipe. Pumped 9 yards of cement. Pulled pipe above water level. Measured cement at 470'. Set grout pipe to 462' pumped 9 yards of cement. Pulled grout pipe. Measured cement at 9' Filled with bentonite to 1' and poured sacrete plug on top. 2 days of pumping cement and measuring cement levels |
|---|

WATER SUPPLY WELL REPORT - Map with location identified must be attached and shall include an approximate scale and north arrow

WASC 53026

7/21/2025

Map of Hole

STATE OF OREGON WELL LOCATION MAP

This map is supplemental to the WATER SUPPLY WELL REPORT

Oregon Water Resources Department

725 Summer St NE, Salem OR 97301
(503)986-0900



LOCATION OF WELL

Latitude: 45.60741667 Datum: WGS84

Longitude: -121.11577778

Township/Range/Section/Quarter-Quarter Section:
WM2.00N14.00E31SESW

Address of Well:

3920 COLUMBIA VIEW DR. E - THE DALLES, OR

Hole Nbr: 6706

Printed: July 21, 2025

DISCLAIMER: This map is intended to represent the approximate location the well. It is not intended to be construed as survey accurate in any manner.

Provided by well constructor

