NOTICE TO WATER WELL CONTRACTOR EGE WATER WELL REPORT
The original and first copy of this report are to be filed with the

AUG 28 19/ STATE OF OREGON
STATE ENGINEER, SALEM, OREGON 7740 TE ENGINEERS type or print) within 30 days from the date of well completion.

SALEM. OREGON

WASH

State Well No. at State Permit No. ..

(1) OWNER:	(11) LOCATION OF WELL:			
Name Ronald G. Unylsteke	County Washington Driller's well number			
Address Rte 4 Box 185-B Hillsboro, Oregon	part of 1/4 Section 19-30r. 1-		2-W	W.M.
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivisi		2, 10	
The state of the s				
If abandonment, describe material and procedure in Item 12.				
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well			
Rotary Driven Domestic M Industrial Municipal Domestic	- total below casing			
Dug ☐ Bored ☐ Irrigation ☐ Test Well ☐ Other ☐	Depth drilled 140 ft. Depth of comp			ft.
6 "Diam. from 0 ft. to 44 ft. Gage 4 wall 5-9/16" Diam. from 40 ft. to 140 ft. Gage 10 gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.			
Diam. fromft. toft. Gage 10 Gage	MATERIAL	From	То	SWL
" Diam. from ft. to ft. Gage	Top soil	0	2	-
PERFORATIONS: Perforated? Yes No.	Brown clay	2	8	
pe of perforator used torch	Soft brown rock	8	14	
	Hard brown rock	14	20	
	Med brown rock	20	28	
80 perforations from 40 ft. to 140 ft.	Hard brown rock	28	48	
perforations from ft. to ft.	Lava rock	48	63	
perforations from ft. to ft.	Broken brown rock	63	90	
perforations from ft. to ft.	Dark brown lava rock	90	115	
perforations from ft. to ft.	Light brown lava rock	115	140	
(7) SCREENS: Well screen installed? ☐ Yes ZNo	Sogra Orowra Custa Cock	113	740	·
Manufacturer's Name				
Type Model No.				
Diam. Slot size Set from ft. to ft.				
Diam. Slot size Set from ft. to ft.				
			-	
(8) WATER LEVEL: Completed well.				1 1 22
Static level 20 ft. below land surface Date 8-24-70				· .
sian pressure lbs. per square inch Date	ALCOHOL . A.S.		<u></u>	L.
(9) WELL TESTS: Drawdown is amount water level is lowered below static level				**
Was a pump test made? ☐ Yes 🏖 No If yes, by whom?				 (;
Yield: gal/min with ft drawdown after	Work started 8-24-70 19 Complet	ed 8-2	24-70	19
" " " "	Date well drilling machine moved off of well	-24-70)	19
" " "		27 70		
Reiler test 10 mil 11 00 mil	Drilling Machine Operator's Certification: This well was constructed under my di	root cum	murialam	Mata
And the state of the diameter in his.	l riais used and information reported above	re are tr	ue to m	ıy beşt
Artesian flow g.p.m. Date	knowledge and belief.		. n .	
Temperature of water Was a chemical analysis made? Yes V No	[Signed] (Drilling Machine Operator)	Date £	· 46	19.70
(10) CONSTRUCTION:	Drilling Machine Operator's Linear No.	~//		
Well seal-Material used Cement	Drilling Machine Operator's License No.	> <i>0-0</i> -	***************************************	
Depth of seal 42 feet	Water Well Contractor's Certification:			
Diameter of well bore to bottom of seal	This well was drilled under my jurisdiction and this report is			
Were any loose strata cemented off? Tyes No Depth	true to the best of my knowledge and belief.			
Was a drive shoe used? 🗌 Yes 🔏 No	NAME Ralph Jurner Drilling (Person, firm or corporation)	.0.	or print)	•••••
Did any strata contain unusable water? 🗌 Yes 💆 No				07/00
Type of water? depth of strata	Address Rts 1 Box 141 Hillsbo	iro, U	regon	9/123
Method of sealing strata off	BODT.	đ	7.	
Was well gravel packed? ☐ Yes 🗷 No Size of gravel:	[Signed] (Water Well Contrac	tor)		
Gravel placed from ft. to ft.		20	•	フふ
It.	Contractor's License No. 247 Date	<u> </u>	? , :	19/0