

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

WATER WELL REPORT STATE OF OREGON

WASH

11AW-23 ed

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

STATE ENGINEER SALEM, OREGON

(Please type or print)

010115

State Well No.

State Permit No.

See GR-333 Deepening

(1) OWNER:

Name Santoro Brothers
Address Rt. 2, Box 760, Beaverton, Oregon

(2) TYPE OF WORK (check):

New Well [] Deepening [X] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Driven []
Cable [] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

CASING INSTALLED:

Threaded [] Welded []
Diam. from X ft. to X ft. Gage
Diam. from X ft. to X ft. Gage
Diam. from X ft. to X ft. Gage

(6) PERFORATIONS:

Perforated? [] Yes [X] No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 50 ft. below land surface Date 3/27/70

Man pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [X] No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
air lift
Bailer test 650 gal./min. with 170 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [X] No

(10) CONSTRUCTION:

Well seal—Material used [X]
Depth of seal [X] ft.
Diameter of well bore to bottom of seal in.
Were any loose strata cemented off? [] Yes [] No Depth
Was a drive shoe used? [] Yes [] No
Did any strata contain unusable water? [X] [] Yes [] No
Type of water? depth of strata
Method of sealing strata off [X]
Was well gravel packed? [] Yes [] No Size of gravel: [X]
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Washington Driller's well number
1/4 1/4 Section 23 T. 1 S R. 2 W. W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 12" to 127 ft

Depth drilled 100 ft. Depth of completed well 227 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: Previously drilled, Brown & gray rock, Hard gray rock, Perforated & decomposed rock, Broken gray rock, etc.

Work started 3/9/70 19 Completed 3/27/70 19
Date well drilling machine moved off of well 3/30/70 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] J. Ellis & Hammerkamp Date 3/31/70, 19
(Drilling Machine Operator)

Drilling Machine Operator's License No. 235

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A. M. Janssen Drilling Co.
(Person, firm or corporation) (Type or print)

Address 21075 S. W. Tualatin Valley Hwy. Aloha, Oregon

[Signed] Edward M. Janssen (Water Well Contractor)

Contractor's License No. 79 Date 3/31/70, 19