

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT
FEB 16 1965
STATE OF OREGON
(Please type or print)
STATE ENGINEER
FEB 25 1965

WASH

G 3315

010287

1/2w-26D

State Well No. _____
State Permit No. _____

(1) OWNER: SALEM, OREGON
Name Robert John Elskamp
Address Rt 2 Box 566
Beaverton Oregon

(2) LOCATION OF WELL:
County Wash Driller's well number _____
1/4 Section 2.6 T. 1S R. 2W W.M.
Bearing and distance from section or subdivision corner
Lot 32 Hazel Meadows
Washington County
map 1680 line 3 Twp. No 32

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded
6" Diam. from 0 ft. to 480 ft. Gage 2510
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used _____
Size of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Well seal—Material used in seal PUDDLLED CLAY
Depth of seal 40 ft. Was a packer used? No
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 30 ft. below land surface Date 2/12/65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 40 gal./min. with 36 ft. drawdown after 5 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 540 ft. Depth of completed well 540 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soil	0	1
YELLOW CLAY	1	5
BROWN SAND	5	25
BLUES "	25	50
BROWN SAND 2 GPM W.	50	55
BLUE SAND	55	65
BLUE CLAY	65	75
YELLOW CLAY	75	120
BLUE CLAY SANDY	120	126
BROWN CLAY	125	165
BLUE CLAY	165	215
RED "	215	275
BLU "	275	295
RED "	295	350
YELLOW "	350	400
SOFT SAND ROCK	400	453
BROKEN DICED ROCK	455	480
MED HARD ROCK	480	490
DECOMPOSED ROCK	490	500
SOFT GREY SAND ROCK	500	520
MED HARD ROCK	520	530
SOFT ROCK WATER	530	540

Work started 1/9 1965 Completed 2/12 1965
Date well drilling machine moved off of well 2/13 1965

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME PAUL E ROSS
(Person, firm or corporation) (Type or print)
Address 2040 SW 122 ALORA ORE.
Drilling Machine Operator's License No. 38
[Signed] Paul E Ross
(Water Well Contractor)
Contractor's License No. 94 Date 2/13 1965