

RECEIVED
 1958
 STATE ENGINEER
 SALEM, OREGON

OBSERVATION WELL

WASH
 REC'D SEP 30 1958
 1/2w-26Q(1)
 State Well No. 010307
 State Permit No. G-965

File Original and
 First Copy with the
 STATE ENGINEER,
 SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON

(1) OWNER:

Name Warren Northwest Inc.
 Address 9860 N.W. Hancock Ln.
Portland, Oregon

(2) LOCATION OF WELL:

County Washington Owner's number, if any—G-965
 1/4 Section T. R. W.M.
 Bearing and distance from section or subdivision corner
262 FT. NORTH AND 1656 FT WEST
FROM THE S.E. CORNER OF SEC 26
TOWNSHIP 150, R 2 WEST, W. 17.
WASHINGTON COUNTY, ORE

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 28 ft. Gage 250
 " Diam. from " ft. to " ft. Gage
 " Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used
 SIZE of perforations in. by in.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.

SCREENS:

Well screen installed Yes No
 Manufacturer's Name
 Type Model No.
 " Slot size Set from " ft. to " ft.
 " Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
 Gravel placed from " ft. to " ft.
 Was a surface seal provided? Yes No To what depth? " ft.
 Material used in seal—
 Did any strata contain unusable water? Yes No
 Type of water? Depth of strata
 Method of sealing strata off

(10) WATER LEVELS:

Static level 165 ft. below land surface Date 9/16/58
 Artesian pressure lbs. per square inch Date

Log Accepted by: **WARREN NORTHWEST INC.**
 [Signed] A. E. Bator Date 9/30, 1958
 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? -
 Yield: gal./min. with ft. drawdown after hrs.
 " " " "
 " " " "
 Bailer test 20 gal./min. with 110 ft. drawdown after 2 hrs.
 Artesian flow g.p.m. Date
 Temperature of water 59 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 6 inches.
 Depth drilled 299 ft. Depth of completed well 299 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay - Brown	0	1.5
Rock - Broken, Set Casings	1.5	28
Rock - medium Basalt	28	196
Rock - Hard Gray Basalt	196	282
Rock - Black Silt	282	299
Water Bearing Rock		
Water level of 1 1/2 ft. at 165 ft.		

Work started 7/25 1958 Completed 9/19 1958

(13) PUMP:

Manufacturer's Name
 Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Jack Barron (Type or print)
 Address 16425 S.W. Hart Rd.
Beaverton, Ore
 Driller's well number 35
 [Signed] Jack Barron (Well Driller)
 License No. 59 Date Sept 29, 1958