

Al Ollivant (owner) WASH

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT DEC 7 1965 STATE ENGINEER SALEM OREGON

WATER WELL REPORT

STATE OF OREGON 010331 (Please type or print)

State Well No. 1/2w-27cd

State Permit No.

(1) OWNER:

Name John L. Moore Address Rt 4 Bx 362 Sherwood, Ore

(2) LOCATION OF WELL:

County Wash Driller's well number 1/4 Section 27 T. 15 R. 2W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ] Irrigation [X] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

6" Diam. from 18" ft. to 361-5 ft. Gage 17 5 9/16" Diam. from 343 ft. to 383 ft. Gage 10

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No Type of perforator used Torch Size of perforations 1/8 in. by 12 in. 52 perforations from 364 ft. to 382 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [X] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal-Material used in seal 200# Bentonite-Mud Depth of seal 20 ft. Was a packer used? No Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? [ ] Yes [X] No Depth Was a drive shoe used? [X] Yes [ ] No Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [ ] Yes [ ] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 12 ft. below land surface Date Nov 22-65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 45 gal./min. with 103 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water Norm Was a chemical analysis made? [ ] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 6 Depth drilled 383 ft. Depth of completed well 383 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Brown clay, Blue sandy clay, Ferratic Rock (Granite), Blue silt, Brown clay, Blue, Brown, Red + Brown sandy clay, Brown, Blue, Brown.

From 305' - 383' - very dirty formation of soft rock or sandstone w/ hard soft spots - sometimes it would stand up - otherwise it would cave & have to change pipe

Work started Oct 5 1965 Completed Nov 22 1965 Date well drilling machine moved off of well Nov 22 1965

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME F.V. Gault (Person, firm or corporation) (Type or print) Address Altha Ave

Drilling Machine Operator's License No. 216-4

[Signed] Al Ollivant (Water Well Contractor)

Contractor's License No. Date Nov 23 1965