

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

# WASH WATER WELL REPORT

# RECEIVED

lobaa  
3/5/2w 3/1/79

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

STATE OF OREGON

NOV - 6 1979

State Well No. 7

(Please type or print)

WATER RESOURCES DEPT

State Permit No. \_\_\_\_\_

010447

(Do not write above this line) SALEM, OREGON

### (1) OWNER:

Name Oregon Berry Packing Co.  
Address Route 4, Box 198 C  
Hillsboro, Oregon 97123

### (2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

### (3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
 Bored

### (4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

### (5) CASING INSTALLED:

10-3/4" Diam. from plus 2 ft. to 165 ft. Gage .250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

### (6) PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used \_\_\_\_\_  
Size of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

### (7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

### (8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No. If yes, by whom?  
625 gal./min. with 110 ft. drawdown after 4 hrs.  
" 820 " 160 " " "  
" 1200 " 260 " " "  
Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
\_\_\_\_\_ dian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

### (9) CONSTRUCTION:

Well seal—Material used Cement  
Well sealed from land surface to 165 ft.  
Diameter of well bore to bottom of seal 15 in.  
Diameter of well bore below seal 10 in.  
Number of sacks of cement used in well seal 32 sacks  
How was cement grout placed? 16 sacks tremmied to bottom and pressured into annular. 16 sacks tremmied into annular at 30' back to surface  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

### (10) LOCATION OF WELL:

County Washington Driller's well number \_\_\_\_\_  
SW 1/4 SE 1/4 Section 31 T. 1 S. R. 2 W. W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

### (11) WATER LEVEL: Completed well.

Depth at which water was first found 224 ft.  
Static level 40 ft. below land surface. Date 10/31/79  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

### (12) WELL LOG:

Diameter of well below casing 10"  
Depth drilled 305 ft. Depth of completed well 300 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Firm brown clay	0	3	
Soft light brown silty clay	3	42	
Soft gray silty clay	42	103	
Sticky blue-gray clay	103	110	
Sticky gray-green clay	110	112	
Soft red-brown decomposed basalt	112	114	
Firm gray basalt	114	122	
Soft red-brown basalt	122	135	
Firm gray-brown basalt	135	224	
Soft red-brown basalt	224	237	water
Firm gray-brown basalt	237	248	
Soft brown basalt	248	258	water
Hard gray basalt w/occ. broken zones	258	305	
Extremely fractured basalt from 280 to 305)	305		water
WELL COMPLETED TO 300'			

Work started 10/16/79 19 Completed 10/31/79 19  
Date well drilling machine moved off of well 11/1/79 19

### Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] [Signature] Date 11/1/79, 19\_\_\_\_  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 751

### Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name A. M. JANSSEN WELL DRILLING CO., INC.  
(Person, firm or corporation) (Type or print)  
Address 21075 SW Tualatin Valley Hwy. Aloha, Or.  
[Signed] [Signature]  
(Water Well Contractor)  
Contractor's License No. 79 Date 11/1/79, 19\_\_\_\_