

RECEIVED
JAN 16 1963

WASH

35 bba

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

WATER WELL REPORT 10514

State Well No. 112W-26N

STATE ENGINEER STATE OF OREGON

State Permit No.

(1) OWNER: M.G. Hagen & A.B. DeKerman?
Name: BEN HEIMECK
Address: 24465 W Baseline Hillsboro Ore

(2) LOCATION OF WELL:
County: WASH
Owner's number, if any—
26 1/4 27 1/4 Section T. 1 S R. 4 W. 2 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
#12" Diam. from #2 ft. to 40 ft. Gage 3/8
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 40 ft.
Material used in seal— CEMENT
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 48 ft. below land surface Date 3/26/62
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] Ben Heimeck 4-2 1962 (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Pump, Pipe
Yield: 150 gal./min. with 107 ft. drawdown after 8 hrs.
" 183 " 300 " 16 "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 12 1/4" to 40"
Depth drilled 408 ft. Depth of completed well 403 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL & YELLOW CLAY	0	19
WEATHERED BASALT	19	26
BLACK BASALT	26	71
CARBON STRIP	71	77
grey BASALT	77	211
Silicose Chert (?)	211	215
MAKING SOME WATER		
BASALT FRAGMENTS		
+ CARBON STRIP MIXED		
in Carbon Strip	215	226
blue BASALT	226	337
CARBON STRIP SHOWING	337	343
OF CHARCOAL & ONE PIECE		
OF #DISTINGUISHABLE		
bark.		
BLUE BASALT	343	372
Porous BLACK BASALT	372	400
WATER BEARING		
blue BASALT +	400	403
STILL BLUE		

Work started 2/21 1962 Completed 3/26/ 1962

(13) PUMP:
Manufacturer's Name: Cornell Pump
Type: Turbine H.P. 1.20

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME: HARTY DRILLING CO.
(Person, firm, or corporation) (Type or print)
Address: 646 E MAIN ST Hillsboro Oregon

Driller's well number
[Signed] [Signature] (Well Driller)
License No. 168 Date 3/27/ 1962