

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

WASH WATER WELL REPORT

STATE OF OREGON

010542

(Please type or print)
Do not write above this line

RECEIVED FEB 6 1969

STATE ENGINEER SALEM, OREGON

State Well No.

1/3W-160

State Permit No.

G-4699

(1) OWNER:

Name Gerald Van Dyke
Address 1000 S.W. 331st. Ave. Hillsboro, Oreg.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 88 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used acetylene torch
Size of perforations 1/8" W in. by 10L. /2" in. apart
180 perforations from 72 ft. to 87 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 6' ft. below land surface Date 5/27/67
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? owner
Yield: 50 gal./min. with 30 ft. drawdown after 3 hrs.
80 " 55 " 8 "
" 100 " 72 " 24 "

Bailey test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date

Temperature of water 50 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Bentonite 100 lbs.
Depth of seal 18' in blue clay ft.
Diameter of well bore to bottom of seal 12" in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Driller's well number
SW 1/4 ME 1/4 Section 2 T. 15 R. 3W W.M.
Bearing and distance from section or subdivision corner
2980' N. 500' E. from the SW corner
of section 1.

(12) WELL LOG:

Diameter of well below casing 0
Depth drilled 87 ft. Depth of completed well 88 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
black soil	0	3	
clay, yellow	3	18	
clay, blue	18	20	
clay, brown & sandy	20	36	
clay, blue & sandy	36	60	
clay, blue & very hard	60	72	
sandy black coarse	72	87	
clay, hard blue	87	88	

Work started 4/12 19 67 Completed 5/27 19 67
Date well drilling machine moved off of well 5/26 19 67

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Gerald Van Dyke Date 1/29, 19-69
(Drilling Machine Operator)
owner

Drilling Machine Operator's License No.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME (Person, firm or corporation) (Type or print)

Address

[Signed] (Water Well Contractor)

Contractor's License No. Date, 19