

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

**WASH WATER WELL REPORT**

STATE OF OREGON  
(Please type or print)

**RECEIVED**

State Well No. 15/3W-2  
G-7031

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

**010566**

(Do not write above this line)

MAY 6 1976

State Permit No.

**WATER RESOURCES DEPT.**

**(1) OWNER:**

Name Gerald Van Dyke  
Address 1000 SW 331st Ave. Hillsboro, Ore. 97123

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Cable  Aug  Driven  Jetted  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal  Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

See sheet attached

Threaded  Welded

**(6) PERFORATIONS:**

Perforated?  Yes  No.

Cutting torch

Type of perforator used

Size of perforations 3/8 in. by 6 in.  
720 perforations from 99'6" ft. to 162 ft.  
228 perforations from 182 ft. to 202'3" ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_ Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? driller  
Yield: 290 gal./min. with 150 ft. drawdown after 6 hrs.  
" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

pressure grouted zone  
intrusion aid, cement  
& admix

Well seal—Material used \_\_\_\_\_  
Well sealed from land surface to 25 & from 60 to 84 ft.  
Diameter of well bore to bottom of seal 36 in.  
Diameter of well bore below seal 36 in.  
Number of sacks of cement used in well seal 96 sacks  
Number of sacks of bentonite used in well seal 50 sacks  
Brand name of bentonite zonalite  
Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: 3/4 - 1/2  
Gravel placed from 84 ft. to bottom ft.

**(10) LOCATION OF WELL:**

County Washington Driller's well number 7603  
1/4 Section 2 T. 1S R. 3W W.M.

Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found \_\_\_\_\_ ft.  
Static level 14 ft. below land surface. Date 11-26-75  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing \_\_\_\_\_

Depth drilled 275 ft. Depth of completed well 223'3" ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
* See sheet attached			
** See sheet attached			

Work started 4-9- 1975 Completed 3-31 1976  
Date well drilling machine moved off of well 3-31 1976

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Mike Schneider Date 4-30, 1976  
(Drilling Machine Operator) 212

Drilling Machine Operator's License No. \_\_\_\_\_

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Schneider Equipment, Inc.  
(Person, firm or corporation) (Type or print)  
Address Star Rt., Box 97 St. Paul, Ore. 97137

[Signed] Mike Schneider  
(Water Well Contractor)

Contractor's License No. 387 Date 4-30, 1976

Material	Gerald Van Dyke	From	To
Top soil		0	4
Brown clay		4	18
Brown silty clay		18	43
Soft gray clay		43	47
Brown silty clay		47	55
Gray sand		55	58
Soft gray clay		58	61
Gray clay		61	63
Soft brown clay		63	70
Gray clay *		70	107
Brown sandy clay		107	111
Small pea gravel		111	114
Gray clay (dry)		114	124
Pea gravel		124	128
Brown sandy clay (dry)		128	141
Pea gravel		141	142
Black clay		142	145
Gray clay		145	174
Brown sandy clay		174	179
Black sand		179	183
Blue clay		183	190
Brown sandy clay		190	199
Gray clay		199	226
Brown sandy clay (dry)		226	241
Gray clay		241	275

RECEIVED

MAY 6 1976

WATER RESOURCES DEPT.  
SALEM, OREGON

\*\* CASING INSTALLED:

12"	Diam. from	+2'6" ft. to	99'6" ft.	Gage	.250
12"		99'6"	162		.375
12"		162	182		.250
12"		182	202'3"		.375
12"		202'3"	222'3"		.250
6"		+2	82		.250 (gravel feed)