## NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be

WATER WELL REPORT

state engineer, salem, oregangles of within 30 days from the date JAN 2 A of well completion.

JAN26 1970 Down write above this line)

5	State	Perm	it"N	OS WA

ST IE ENGINEER	010686		
(1) OWNER: SALEM. OREGON	(11) LOCATION OF WELL:		
Name Donald C Jesse	County Wash Driller's well number		
Address Rt 2 Box 23 Hillsboro Oragon 97/23	34 34 Section T. R.	W.M.	
	Bearing and distance from section or subdivision corner		
(2) TYPE OF WORK (check):	355'N 81°W from the SE con	ner	
New Well ☑ Deepening □ Reconditioning □ Abandon □	of NE 4 of the XIW & of Section	13	
If abandonment, describe material and procedure in Item 12.	Top 15 Range 3W W.M.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing		
Rotary   Driven   Domestic   Industrial   Municipal	Depth drilled /94 ft. Depth of completed well /94/	ft.	
Dug	Formation: Describe color, texture, grain size and structure of mat-		
CASING INSTALLED: Threaded D Welded T 70 It to 194 ft. Gage 7	and show thickness and nature of each stratum and aquifer penet with at least one entry for each change of formation. Report each c in position of Static Water Level as drilling proceeds. Note drilling	rated, hange	
" Diam. from ft. to ft. Gage	MATERIAL From To	SWL	
ft. toft. Gage	Top soil 0 1		
PERFORATIONS: Perforated?   Yes  No.	brown clay 1 32		
Type of perforator used Knock - out	brown Sandy clay 32 87		
Size of perforations 3" in. by 2" in.	hard blue clay 87 101		
perforations from 98 tt. to 106 tt.	coarse gravel 101 108		
perforations from 152 tt. to 194 tt.	blue sandy clay 108 150 tine gravel 150 154		
perforations from ft. to ft.	blue sand 154 187		
perforations from ft. to ft.	tine gravel 187 191		
perforations from ft. to ft.	blue sandy clay 191 194		
(7) SCREENS: Well screen installed?   Yes INO			
Manufacturer's Name			
Type Model No		<del></del>	
Diam Slot size Set from ft. to ft.			
Diam. Slot size Set from ft. to ft.			
(8) WATER LEVEL: Completed well.			
Static level 12 ft. below land surface Date May 69		,	
an pressure lbs. per square inch Date		·,	
(9) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? Yes 🗌 No If yes, by whom?	- 10 - m	*0	
Yield: 100 gal./min. with 120 ft. drawdown after 10 hrs.		1969	
" " " "	Date well drilling machine moved off of well May	1969	
" " "	Drilling Machine Operator's Certification:		
Bailer test gal./min. with ft. drawdown after hrs.	This well was constructed under my direct supervision. It rials used and information reported above are true to my		
Artesian flow g.p.m. Date	knowledge and belief.		
Temperature of water Was a chemical analysis made? [] Yes 🗷 No	[Signed] Donald Ckase Date lan 24, 1	9. <b>7Q</b>	
(10) CONSTRUCTION:	(Drilling Machine Operator)  Drilling Machine Operator's License No.		
Well seal-Material used Benton te			
Depth of seal 40 ft.	Water Well Contractor's Certification:		
Diameter of well bore to bottom of sealin.	This well was drilled under my jurisdiction and this reportrue to the best of my knowledge and belief.	rt is	
Were any loose strata cemented off? ☐ Yes ☐ No Depth	NAME		
Did any strata contain unusable water?  Yes No	(Person, firm or corporation) (Type or print)		
Type of water? depth of strata	Address	******	
Method of sealing strata off			
Was well gravel packed?  Yes No Size of gravel:	[Signed](Water Well Contractor)	********	
Gravel placed fromft. toft.	Contractor's License No		
It. W	Contraction a Literact No Date		