

WATER WELL REPORT
STATE OF OREGON

#5
Should be
liner & not
casing
Dr. D.
Caw 7/29/82

WASH 010741 State Well No.
RECEIVED
JUN 8 1982
State Permit No. 2/3W-178d

WATER RESOURCES DEPT

Recondition

(1) OWNER:
Name Donald B. Anderson
Address Route 4, Box 137L
City Cornelius, Oregon State 97113

(10) LOCATION OF WELL:
SALEM, OREGON
County Washington Driller's well number
SE 1/4 SE 1/4 Section 17 T. 1 S R. 3 W. W.M.
Tax Lot # Lot Blk Subdivision
Address at well location:

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(11) WATER LEVEL: Completed well.
Depth at which water was first found -- ft.
Static level 20 ft. below land surface. Date 5/28/82
Artesian pressure lbs. per square inch. Date

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
 Bored Thermal: Withdrawal Reinjection

(12) WELL LOG: Diameter of well below casing -- ft.
Depth drilled -- ft. Depth of completed well -- ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

(5) CASING INSTALLED: Steel Plastic
Threaded Welded
6" Diam. from 10 ft. to 340 ft. Gauge .188
" Diam. from ft. to ft. Gauge

MATERIAL	From	To	SWL
Hole blocked @ 335', and cleaned out to bottom.			
Liner installed - did not fail to bottom.			

LINER INSTALLED:
" Diam. from ft. to ft. Gauge

(6) PERFORATIONS: Perforated? Yes No
Type of perforator used Torch
Size of perforations 1/4 in. by 12" in.
60 perforations from 310 ft. to 340 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 180 gal./min. with 180 ft. drawdown after 2 hrs.
Air test gal./min. with drill stem at ft. hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

Work started 5/27/82 19 Completed 5/28/82 19
Date well drilling machine moved off of well 5/28/82 19

(9) CONSTRUCTION: Special standards: Yes No
Well seal—Material used X
Well sealed from land surface to X ft.
Diameter of well bore to bottom of seal X in.
Diameter of well bore below seal X in.
Number of sacks of cement used in well seal X sacks
How was cement grout placed? X
Was pump installed? Type X HP Depth X ft.
Was a drive shoe used? Yes No Plugs X Size: location X ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata X
Method of sealing strata off X
Was well gravel packed? Yes No X Size of gravel: X
Gravel placed from X ft. to X ft.

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date 6/4/82
(Drilling Machine Operator)
Drilling Machine Operator's License No. 751

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name A. M. JANNSEN WELL DRILLING CO., INC.
(Person, firm or corporation)
Address 21075 SW Tualatin Valley Hwy. Aloha, Or.
[Signed] Date June 4, 1982
(Water Well Contractor)
Contractor's License No. 79 Date June 4, 1982, 19.....