NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT OREGON 97310 SALEM, OREGON 97310 within 30 days from the date of well completion.

## WATER WELL BEFORE ENED

STATE OF OREGONAPR 71978

010760 (Do not write above ATTER, RESOURCES DETAIL Permit No. G-8146, G-10308)
SALEM. OREGON

	The state of the s			
(1) OWNER:	(10) LOCATION OF WELL:			
Name Donald B. Anderson	County Washington Driller's well number			
Address Route 2, Box 439B	SE 1/4 SE 1/4 Section 17 T. 1 S R. 3 W. W.M.			
Cornelius, Oregom 97113	Bearing and distance from section or subdivision corner			
(2) TYPE OF WORK (check):	San anna Control			
New Well 🐹 Deepening 🗍 Reconditioning 🗋 Abandon 🗋				
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	ell.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	100			
Potony M Drivon D	90		· .	ft.
Domestic   Industrial   Municipal   Dug   Bored   Irrigation 🗷 Test Well   Other				
Dug   Bored   Irrigation & Test Well   Other	Artesian pressure lbs. per squar	e inch.	Date .	
CASING INSTALLED:       Threaded □       Welded №         0-5/8 " Diam. from plus 1 ft. to       ft. to       78 ft. Gage • 250         " Diam. from ft. to       ft. Gage         " Diam. from ft. to       ft. Gage	(12) WELL LOG: Diameter of well below casing 8th  Depth drilled 370 ft. Depth of completed well 370 ft.  Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,			
PERFORATIONS: Perforated?   Yes  No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.			
Type of perforator used	MATERIAL	From	То	swL
Size of perforations in. by in.	Brown clay	0	8	
perforations from ft, to ft.	Red-brown clay	8		·
perforations from ft. to ft.	Brown clay w/weathered rock	20	40	
perforations from ft. to ft.	Weathered brown basa1t	40	70	
(7) SCREENS: Well screen installed?   Yes X No	Gray-brown basalt	70	87	
Manufacturer's Name	Brown basalt-occ. broken	87	105	
Type Model No	Gray-black basalt-occ.fracture	1 105	120	
Diam. Slot size Set from ft. to ft.	Brown & gray-brown basalt-occ.	100	100	10
Diam. Slot size Set from ft. to ft.	broken Black & gray-black basalt-occ.	120	160	10 gpm
	broken streak	160	200	20 gpm
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Hard gray basalt-occ.crevice	200	250	5 gpm
Was a pump test made? ☐ Yes ☑ No If yes, by whom?	Broken brown basalt	250	260	15 gpm
airlift 300 gal./min. with 200 ft. drawdown after hrs.	Gray-brown basalt	260	270	
250 150	Black basalt-occ.fractured	270	310	10 gpm
170 100 "	Hard gray basalt	310	338	
	Broken black basalt & blue			<del></del>
Bailer test gal./min. with ft. drawdown after hrs.	claystone	338	341	
Artesian flow g.p.m.	Broken brown basalt Gray brown basalt	341	358	230 gpm
nperature of water Depth artesian flow encountered ft.	Work started $3/30/78$ 19 Completed $4/4/78$ 19			
(9) CONSTRUCTION:	Date well drilling machine moved off of well $4/4/78$ 19			
Well seal-Material used Cement grout & 5% gel.	Drilling Machine Operator's Certification:			
Well sealed from land surface to	This well was constructed under my direct supervision.  Materials used and information reported above are true to my best knowledge and belief.			
Diameter of well bore below seal8 in.  Number of sacks of cement used in well seal8 sacks	[Signed] Date 4/5/78, 19			
How was cement grout placed? Poured in dry annular	Drilling Machine Operator's License No. 523			
space. Bottom seal 4 sacks; granular bentonite and drill cuttings, Top seal 0 - 25' 4 sacks	Water Well Contractor's Certification:			
2	This well was drilled under my jurisdiction and this report is			
Was a drive shoe used? 🗌 Yes 🏖 No Plugs Size: location ft.	true to the best of my knowledge and belief.  Name A. M. JANNSEN DRILLING CO.			
Old any strata contain unusable water? Yes No  Type of water? depth of strata	(Person, firm or corporation) (Type or print)  Address 21075 SW Tualatin Valley Hwy, Aloha, Or.			
Method of sealing strata off	$\mathcal{L}_{\mathcal{A}}$			
Was well gravel packed? [] Yes 🗷 No Size of gravel:	[Signed] (Water Well Contractor)			
Gravel placed from ft. to ft.	Contractor's License No. 79 Date 4/5/78 19			