

STATE OF OREGON  
**WATER WELL REPORT**  
 (as required by ORS 537.765)

**RECEIVED**  
 MAY 28 1985  
 WATER RESOURCES DEPT  
 SALEM, OREGON  
 COPY TO BE FILED OR PRINT IN INK

WASH  
 010876

15/3W-24dc

(for official use only)

**(1) OWNER:**

Name DONNIS WHITE  
 Address 817 NE HOOD  
 City HILLSBORO State Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary Air  Driven  Domestic  Industrial  Municipal   
 Rotary Mud  Dug  Thermal:  Withdrawal  ReInjection   
 Cable  Bored  Other:  Piezometric  Grounding  Test

**(4) PROPOSED USE (check):**

Steel  Plastic   
 Threaded  Welded   
 Gauge 250

**(5) CASING INSTALLED:**

6" Diam. from 12" ft. to 174" ft. Gauge 250  
 " Diam. from " ft. to " ft. Gauge "

**LINER INSTALLED:**

NO Steel  Plastic   
 Threaded  Welded   
 " Diam. from " ft. to " ft. Gauge "

**(6) PERFORATIONS:**

Perforated?  Yes  No  
 Size of perforations in. by in.  
 perforations from " ft. to " ft.  
 perforations from " ft. to " ft.  
 perforations from " ft. to " ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
 Manufacturer's Name ..... Model No. ....  
 Type ..... Slot Size ..... Set from ..... ft. to ..... ft.  
 Diam. .... Slot Size ..... Set from ..... ft. to ..... ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 gal./min. with ft. drawdown after hrs.  
 Air test 100 gal./min. with drill stem at 380 ft. 3 hrs.  
 Bailer test gal./min. with ft. drawdown after hrs.  
 Artesian flow g.p.m.  
 Temperature of water 54 Depth artesian flow encountered ..... ft.

**(9) CONSTRUCTION:**

Special standards: Yes  No   
 Well seal—Material used Cement  
 Well sealed from land surface to 174 ft.  
 Diameter of well bore to bottom of seal 10 in.  
 Diameter of well bore below seal 6 in.  
 Amount of sealing material 60 sacks  pounds   
 How was cement grout placed? Pumped in  
 Was pump installed? NO Type ..... HP ..... Depth ..... ft.  
 Was a drive shoe used?  Yes  No Plugs ..... Size: location ..... ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of Water? ..... depth of strata .....  
 Method of sealing strata off .....  
 Was well gravel packed?  Yes  No Size of gravel: .....  
 Gravel placed from ..... ft. to ..... ft.

**(10) LOCATION OF WELL by legal description:**

County Washington SW<sup>1/4</sup> SE<sup>1/4</sup> of Section 24 of  
 Township 15 Range 3W WM.  
 (Township is North or South) (Range is East or West)  
 Tax Lot ..... Lot ..... Block ..... Subdivision .....  
 MAILING ADDRESS OF WELL (or nearest address) .....

**(11) WATER LEVEL of COMPLETED WELL:**

Depth at which water was first found 250 ft.  
 Static level 30 ft. below land surface. Date 5-15-85  
 Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:**

Diameter of well below casing 6  
 Depth drilled 382 ft. Depth of completed well 382 ft.  
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	1	
BROWN CLAY	1	15	
GRAY CLAY	15	25	
BROWN CLAY	25	35	
RED CLAY	35	40	
BROWN CLAY	40	160	
BASALT	160	382	

**AIR TEST**

20 GPM FROM 75		
25 " " " 100		
40 " " " 125		
50 " " " 150		
80 " " " 168		
100 " " " 280		
100 " " " 380		

Date work started 5-5-85 /completed 5-15-85  
 Date well drilling machine moved off of well 5-15-85

**(unbonded) Water Well Constructor Certification (if applicable):**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Cyril Vandehy Date 5-23-85, 19 .....

**(bonded) Water Well Constructor Certification:**

Bond SB0432975 Issued by: WALTZ + WIEBER  
 (number) (Surety Company Name)  
 On behalf of Cyril Vandehy  
 (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Cyril Vandehy  
 (Water Well Constructor)

(Dated) 5-28-85

NOTICE TO WATER WELL CONSTRUCTOR  
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
 SALEM, OREGON 97310  
 within 30 days from the date of well completion.

SP\*46866-690