

WASH 10935

010935 WATER WELL REPORT

6-20-64
Customer's
Correction
NW 1/4 SE 1/4

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM 10, OREGON
within 30 days from the date
of well completion.

JUN 2 1964

STATE OF OREGON
(Please type or print)

State Well No. 113W-25R
State Permit No.

(1) OWNER:

Name Charles W. Aldred
Address Rt. 2 Box 341
Cornelius, Ore.

(2) LOCATION OF WELL:

County Washington Driller's well number
SE 1/4 SE 1/4 Section 25 T. 1S R. 3W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 5.6 ft. Gage 2.50
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Sand + Cement
Depth of seal 30 ft. Was a packer used? no
Diameter of well bore to bottom of seal 8 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 10 ft. below land surface Date 3/19/64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 17 gal./min. with 30 ft. drawdown after 4 hrs.
Artesian flow g.p.m. Date
Temperature of water 54 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing
Depth drilled ft. Depth of completed well ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	3
Sandy clay brown	3	45
boulders	45	50
Shattered rock	50	55
Solid green rock	55	68
water rock	68	69
Solid black basalt	69	71

Work started 3/12/1964 Completed 3/19/1964
Date well drilling machine moved off of well 3/19/1964

(13) PUMP:

Manufacturer's Name Fairway
Type: Submersible 68 H.P. 1

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME American Well Drilling
(Person, firm or corporation) (Type or print)
Address 143 SE 95th Ave
Drilling Machine Operator's License No. 329
[Signed] W. C. Smith
(Water Well Contractor)
Contractor's License No. 375 Date 3/30/64, 19

NOTE TO WATER WELL CONTRACTOR

This report and test logs
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

REG. STATE OF OREGON
(Please type or print)

State Well No. _____

State Permit No. _____

(1) CONTRACTOR:

Name Charles W Aldred
Address Rt. 2 Box 541
GREEN HOLLOW & CO
ENGINEERS & DRILLERS

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" 22 " 100 " 4 "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.a. Date
Temperature of water 54° Was a chemical analysis made? Yes No

(2) LOCATION OF WELL:

County Washington Driller's well number _____
T. 15 R. 3W S. 25 W.M.
Location and distance from section or subdivision corner
"East Laurel Acres"

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled _____ ft. Depth of completed well _____ ft.
Formation: Describe in color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Felted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 56 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
Size of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Type _____ Slot size _____ Set from _____ ft. to _____ ft.
Type _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal sand and cement
Depth of seal 30 ft. Was a packer used? no
Diameter of well bore to bottom of seal _____ in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing stream off _____

(10) WATER LEVELS:

Static level 60 ft. below land surface Date 3/17/64
Artesian pressure _____ lbs. per square inch Date _____

MATERIAL	FROM	TO
Top soil	0	3
sandy clay (brown)	3	45
boulders	45	50
shattered rock	50	55
solid green rock	55	65
water rock	65	69
solid black basalt	69	71
soft Basalt	71	160
soft sand stone	160	170
Hard Black Basalt	170	180

Received from Drinking Water Program of Oregon Health Authority. They received log from current owner, West Laurel Acres Water Co. Probably a corrected well log or a deepening record for WASH 10935.

K. G. Wazniak
Groundwater Section
10-1-2012

Work started 3/12/1964 Completed 3/19/1964
Date well drilling machine moved off of well 3/19 1964

(13) PUMP:

Manufacturer's Name Sairway
Type: _____ H.P. 1

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME AMERICAN Well Drilling
Address 143 S.E. 95th Ave
Drilling Machine Operator's License No. 329
[Signed] _____ (Water Well Contractor)
Contractor's License No. 375 Date 3/30, 1964