

RECEIVED

WASH

G-7266
G-5532010937

25 M

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

State Well No. 113w-25M

State Permit No.

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE OF OREGON
(Please type or print)

(1) OWNER:

Name Ira Barby

Address Rt 2 Box 318
Cornelius Ore

(2) LOCATION OF WELL:

County Wash Driller's well number _____

$\frac{1}{4}$ Section 26 T. 15 R. 3W W.M.

Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

Draw Well Deepening Reconditioning Abandon

abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL: Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED: Threaded Welded

_____ " Diam. from _____ ft. to _____ ft. Gage _____

6 " Diam. from 0 ft. to 84 ft. Gage 17#

_____ " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No

Type of perforator used _____

Size of perforations _____ in. by _____ in.

_____ perforations from _____ ft. to _____ ft.

_____ perforations from _____ ft. to _____ ft.

_____ perforations from _____ ft. to _____ ft.

_____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal 100# Bentonite

Depth of seal 18 ft. Was a packer used? no

Diameter of well bore to bottom of seal 10 in.

Were any loose strata cemented off? Yes No Depth _____

Was a drive shoe used? Yes No

Was well gravel packed? Yes No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

Did any strata contain unusable water? Yes No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

(10) WATER LEVELS:

Static level 11 ft. below land surface Date Sept 1-65

Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? _____

Yield: 60 gal./min. with 74 ft. drawdown after 4 hrs.

" " " " "

" " " " "

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water Normal Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 6

Depth drilled 206 ft. Depth of completed well 206 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|--------------------------|------|-----|
| <u>Brown Sandy clay</u> | 0 | 19 |
| <u>Blue silt</u> | 19 | 43 |
| <u>soft brown clay</u> | 43 | 62 |
| <u>soft crumbly rock</u> | 62 | 84 |
| <u>hard rock</u> | 84 | 89 |
| <u>soft</u> ✓ | 89 | 103 |
| <u>hard</u> ✓ | 103 | 117 |
| <u>Very hard</u> ✓ | 117 | 133 |
| <u>soft</u> ✓ | 133 | 148 |
| <u>med</u> ✓ | 148 | 165 |
| <u>hard</u> ✓ | 165 | 190 |
| <u>soft</u> ✓ | 190 | 206 |

Work started Aug 4 1965 Completed Sept 1 1965

Date well drilling machine moved off of well Sept 1 1965

(13) PUMP:

Manufacturer's Name _____

Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Bill Gaunt (Person, firm or corporation) (Type or print)

Address Flora Dr

Drilling Machine Operator's License No. 4-216

[Signed] Bill Gaunt (Water Well Contractor)

Contractor's License No. 4 Date Sept 1, 1965