

(1) OWNER:

Name William Unger  
Address Rt. 1  
Cornelius, Oregon

STATE ENGINEER  
SALEM, OREGON

(2) LOCATION OF WELL:

County Wash Owner's number, if any—  
R. F. D. or Street No.  
Bearing and distance from section or subdivision corner  
THE WELL IS LOCATED 1123.60 N. AND  
729.12 FT. E. FROM THE SW. CORNER OF  
SECTION 26 T. 15. R. 3 W. W.D. AND BEARS  
N. 31.0 S. E. 138.71 FEET THEREFROM.

(3) TYPE OF WORK (check):

New well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) EQUIPMENT:

Rotary   
Cable   
Dug Well

(6) CASING INSTALLED:

Table with columns: FROM, ft. to, ft., Diam., Gage or Wall, Diameter of Bore, from ft., to ft. Includes rows for casing specifications and shoe/well ring details.

(7) PERFORATIONS:

Table with columns: Type of perforator used, No. of perforations, in., length, by, in. Includes rows for perforation details.

SCREENS:

Give Manufacturer's Name, Model No. and Size

(8) CONSTRUCTION:

Was a surface sanitary seal provided?  Yes  No To what depth ft.  
Were any strata sealed against pollution?  Yes  No  
If yes, note depth of strata Surface water  
METHOD OF SEALING Driving casing

(9) WATER LEVELS:

Depth at which water was first found 100 ft.  
Standing level before perforating ft.  
Standing level after perforating 130 ft.

Log Accepted by:  
[Signed] \_\_\_\_\_ Dated \_\_\_\_\_, 19\_\_\_\_  
Owner

(10) WELL TESTS:

Was a pump test made?  Yes  No If yes, by whom? Well Driller  
Yield: 115 gal./min. with 75 ft. draw down after 4 hrs.  
Artesian flow ..... g.p.m.  
Shut-in pressure ..... lbs. per square inch.  
Bailer test ..... g.p.m. with ..... ft. drawdown  
Temperature of water Was a chemical analysis made?  Yes  No  
Was electric log made of well?  Yes  No

(11) WELL LOG:

Diameter of well, 8 inches.  
Total depth 400 ft. Depth of completed well 400 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.  
0 ft. to 40 ft. Clay  
40 " 110 " Sand stone  
110 " 227 " Hard gray basalt  
227 " 232 " Soft brown rock  
232 " 369 " Hard gray basalt  
369 " 400 " Black rock, water-bearing

Ground elevation at well site ..... feet above mean sea level.  
Work started 8-4-56 19 , Completed 1-19-57 19

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A.M. Janssen Drilling Co.  
(Person, firm, or corporation) (Typed or printed)  
Address Aloha, Oregon  
Driller's well number  
[Signed] Edward M. Janssen  
(Well Driller)  
License No. 79 Dated 2-7-57, 19\_\_\_\_