

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED

DEC 4 1974

State Well No.

15/4W-10

STATE ENGINEER

State Permit No.

SALEM, OREGON

(1) OWNER:

Name Howard Wable
Address RT 1 Box 206 D Forest Grove Ore

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒
Cable ☒
Dug ☐

Driven ☐
Jetted ☐
Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒

6" Diam. from 71 ft. to 40 ft. Gage 4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
"air lifted" 3 1/2 APM from
"200 ft after 1 hr"
Bailer test gal./min. with 153 ft. drawdown after 1 hrs.
Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 37 ft.
Diameter of well bore to bottom of seal 9 1/2 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 10 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Washington Driller's well number
1/4 1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner

Sec 10 T1S R42W

(11) WATER LEVEL: Completed well.

Depth at which water was first found 45 ft.

Static level 47 ft. below land surface. Date 11/18/74

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 200 ft. Depth of completed well 200 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	2	
Red Clay	2	15	
Brown "	15	24	
Brown Shal	24	35	
Blue Sand Rock	35	80	
Hard Blue Shal	80	200	

Work started 11/18 1974 Completed 11/18 1974

Date well drilling machine moved off of well 11/18 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] Harold M. Duffin Date 12/2, 1974
(Drilling Machine Operator)

Drilling Machine Operator's License No. 82

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name Harold M. Duffin
(Person, firm or corporation) (Type or print)

Address 729 N Main

[Signed] Harold M. Duffin
(Water Well Contractor)

Contractor's License No. 117 Date 12/2, 1974