NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the WATER WELL REPORT State Well No. STATE ENGINEER, SALEM, OREGON 97316 within 30 days from the date of well completion. (Please type or pin) (Please type or pin) (Do not write above this line) (G-4422

G-4422

	į.		
2/	1 112	 5	E
		 <u> </u>	**********

(1) OWNER:	(11) LOCATION OF WELL:			
Name Harry Werner	County Washington Driller's well number			
Address Rt.1, Box 436	14 14 Section 5 T. 2 R. 1 W W.M.			
Beaverton, Oregon, 97005				
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner			
New Well ☑ Deepening □ Reconditioning □ Abandon □				
If abandonment, describe material and procedure in Item 12.				
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(10) WINT TOO			
Rotary Driven Domestic M Industrial Municipal Domestic Do	(12) WELL LOG: Diameter of well below casing 8			
Dug	Depth drilled 229 ft. Depth of completed well 229 ft.			
CASING INSTALLED: Threaded Welded Welded Std.	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.			
	MATERIAL From To SWL			
" Diam. from ft. to ft. Gage	top soil 0 5			
PERFORATIONS: Perforated? Yes X No.	clay - brown 5 22			
Type of perforator used	22 35			
	rock - brown 33 100			
Size of perforations in. by in.	" " hard 100 118			
perforations fromft. toft.	" black 118 130			
perforations from	brown-not hard 130 155			
perforations from	" little water, brown 155 160			
perforations from ft. to ft.	* brown 160 166			
(7) SCREENS: Well screen installed? Yes No	11ttle water 181 201			
Manufacturer's Name	Dlack- little			
Type Model No.	water in seams 201 229			
Diam Slot size Set from ft. to ft.				
Diam. Slot size Set from ft. to ft.				
(8) WATER LEVEL: Completed well.				
stric level 150 ft. below land surface Date NOV. 7, 6				
Artesian pressure lbs. per square inch Date				
(9) WELL TESTS: Drawdown is amount water level is				
lowered below static level				
Was a pump test made? ☐ Yes ♣No If yes, by whom?				
d: gal./min. with ft. drawdown after hrs.	Work started Oct. 26 1967 Completed Nov. 7 1967			
" " "	Date well drilling machine moved off of well 19			
n n	Drilling Machine Operator's Certification:			
Bailer test 30 gal./min. with 0 ft. drawdown after 2 hrs.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best			
Artesian flow g.p.m. Date	knowledge and belief.			
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No	[Signed] & Machine Operator Date 160 31, 1967			
(10) CONSTRUCTION:	Of the			
Well seal—Material used Betonite	Drilling Machine Operator's License No. 217			
Depth of seal 20 ft.	Water Well Contractor's Certification:			
Diameter of well bore to bottom of seal in.	This well was drilled under my jurisdiction and this report is			
Were any loose strata cemented off? Yes No Depth	true to the best of my knowledge and belief.			
Was a drive shoe used? ☐ Yes ☐ Yo	NAME Barron & Strayer (Person, firm or corporation) (Type or print)			
Did any strata contain unusable water? Yes No	Pt 1 Por OFA Boomerton One			
Type of water? depth of strata	Address no. 1, Box 254, Beaverton, Ore.			
Method of sealing strata off	[Signed] A A Sarron			
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	(Water Well Contractor)			
Gravel placed from ft. to ft.	Contractor's License No. 35 Date Nov. 21 19 67			