

WASH  
011573

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

RECEIVED  
JAN 17 1967  
STATE OF OREGON  
(Please type or print)  
ENGINEER  
EM. OREGON

G-2309  
G-2170

State Well No. 2/10-10 <sup>dba</sup>  
State Permit No. \_\_\_\_\_

(1) OWNER:

Name William B. Sanders  
Address 11165 SW Naeva St.  
Tigard, Oregon

(2) LOCATION OF WELL:

County Washington Driller's well number 2-67  
NW 1/4 SE 1/4 Section 10 T. 2S R. 1W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
8" Diam. from 0 ft. to approx 22 ft. Gage 0.250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
\_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal \_\_\_\_\_  
Depth of seal \_\_\_\_\_ ft. Was a packer used? \_\_\_\_\_  
Diameter of well bore to bottom of seal \_\_\_\_\_ in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level 100 ft. below land surface Date 1/9/67  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
" " " " " "  
" " " " " "  
Bailer test 40 gal./min. with no ft. drawdown after 1 hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water 53 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 8"  
Depth drilled 330 ft. Depth of completed well 330 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>drilled</u> <u>This well originally by J.E. Klundt in about 1953 to a depth of 125 feet. Eight inch hole was drilled to 100 feet and reduced to six inch hole to 125 feet. Columbia River Basalt from about 15 feet on.</u>		
Rock, dark grey, hard	125	165
Rock, grey, med. hard	165	168
Rock, Brown, med. soft	168	173
Rock, Brown, soft	173	186
Rock, Brown, white clay seams	186	193
Rock, Grey with brown seams (water)	193	220
Rock, Dark grey, hard	220	238
Rock, Brown	238	263
Rock, Grey with brown seams	263	295
Rock, Dark grey, med. hard	295	303
Rock, grey with brown seams	303	317
Rock, Brown honeycomb (water)	317	326
Rock, grey	326	330

Work started Dec. 13, 1966 Completed Jan. 9, 1967  
Date well drilling machine moved off of well Jan. 9, 1967

(13) PUMP:

Manufacturer's Name Berkley—2 units  
Type: Submersibles H.P. and 1 1/2

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Steinman Bros. (Person, firm or corporation) (Type or print)  
Address 15112 SE McLoughlin, Milwaukie, Ore.

Drilling Machine Operator's License No. 68

[Signed] Steinman Bros. (Water Well Contractor)

Contractor's License No. 1 Date Jan. 16, 1967