

WASH 011587

RECEIVED APR 24 1967

G-3777

NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE OF OREGON (Please type or print)

STATE ENGINEER STATE OF OREGON

State Well No. 2/1w-10 N State Permit No.

(1) OWNER:

Name Tualatin Development Co. Address 15475 SW Pacific Hwy. Tigard, Ore.

(2) LOCATION OF WELL:

County Washington Driller's well number 1/4 Section 10 T. 25 R. 1W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other [] Rotary [X] Cable [X] Dug [] Driven [] Jetted [] Bored []

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 248 ft. Gage .250 Threaded [] Welded [X]

(7) PERFORATIONS:

Perforated? [] Yes [X] No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite Depth of seal 247 ft. Was a packer used? No Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [] Yes [X] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 47 ft. below land surface Date 1-19-67 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level A.M. Was a pump test made? [X] Yes [] No If yes, by whom? Janssen Drilling Co. Yield: 190 gal./min. with 23 ft. drawdown after 8 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 8" to 350' 8" to 805' Depth drilled 805 ft. Depth of completed well 805 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Brown clay, Sandy blue clay, Brown clay, Decomposed rock, Hard black rock, Clay & rock interbed, Brown & black rock - water bearing, Very hard gray rock, Soft black rock - 25 to 30 gpm, Hard gray rock with crevices, Hard black basalt, Gray hard basalt, Loose rock, lost cuttings, Hard black basalt, Lost cuttings, Hard black basalt.

Work started 5-19 19 66 Completed 1-19 19 67 Date well drilling machine moved off of well 1-19 19 67

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A. M. Janssen Drilling Co. (Person, firm or corporation) (Type or print) Address 21075 SW Tual. Villy. Hwy. Aloha, Ore.

Drilling Machine Operator's License No 177

[Signed] (Water Well Contractor)

Contractor's License No. 79 Date 4-18 19 67