

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

WASH
011806

State Well No. 2/10-16 K

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE OF OREGON
(Please type or print)

G-3240

State Permit No. _____

(1) OWNER:

Name M. L. Terril
Address 17260 S. W. 131st
Tigard, Oregon

(2) LOCATION OF WELL:

County Washington Driller's well number 39-65
1/4 SE 1/4 Section 16 T. 28 R. 1W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

6" Diam. from 0 ft. to 228 ft. Gage 0.250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled clay.
Depth of seal 22 ft. Was a packer used? No
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 35 ft. below land surface Date 8/9/65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
" " " "
" " " "
Bailer test 30 gal./min. with 190 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 54° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 285 ft. Depth of completed well 285 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay, yellow sandy	0	22
Quicksand, brown	22	45
Silt, blue & grey packed	45	58
Clay, blue sticky	58	70
Sand, blue	70	95
Clay, orange	95	112
Clay, grey	112	158
Clay, soft tan	158	187
Conglomerate, brown	187	218
Rock, decomposed brown	218	228
Rock, grey-yellow seams	228	255
Rock, brown	255	263
Rock, black	263	271
Rock, brown, seamy	271	275
Rock, black	275	285

RECEIVED
AUG 16 1965

STATE ENGINEER
SALEM, OREGON

Work started Aug. 2 1965. Completed Aug. 9 1965
Date well drilling machine moved off of well Aug. 11 1965

(13) PUMP:

Manufacturer's Name Myers
Type: Submersible H.P. 2

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Steinman Bros.
(Person, firm or corporation) (Type or print)
Address 15112 S. E. McLoughlin Blvd. Milwaukie, Ore.

Drilling Machine Operator's License No. 68

[Signed] Steinman Bros.
(Water Well Contractor)

Contractor's License No. I Date Aug. 12, 1965