

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

RECEIVED NOV 7 1960

WATER WELL REPORT STATE OF OREGON

WASH 011962

2/1w-23A

State Well No.

State Permit No.

(1) OWNER: STATE ENGINEER Name Clay Barton Address 218 Builders Exchange Portland, Ore.

(2) LOCATION OF WELL: County Wash. Owner's number, if any-- NE 1/4 NE 1/4 Section 23 T. 2S R. 1W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): New Well [x] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check): Domestic [x] Industrial [] Municipal [] Irrigation [x] Test Well [] Other [] (5) TYPE OF WELL: Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED: 8" Diam. from 0 ft. to 174 ft. Gage 5/16 6" Diam. from 171 ft. to 189 ft. Gage 1/4

(7) PERFORATIONS: Perforated? [x] Yes [] No Type of perforator used Torch SIZE of perforations 3/16 in. by 12 in. 1 per ft. perforations from 171 ft. to 189 ft.

(8) SCREENS: Well screen installed [] Yes [x] No Manufacturer's Name Type Model No. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [] Yes [x] No To what depth? ft. Material used in seal-- Did any strata contain unusable water? [] Yes [x] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 32 ft. below land surface Date 11/1/60 Artesian pressure lbs. per square inch Date

Log Accepted by: [Signed] Date 19

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [x] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 45 gal./min. with 100 ft. drawdown after 2 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG: Diameter of well 8 inches. Depth drilled 189 ft. Depth of completed well 189 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include: Brown hard clay (0-6), Blue silt & sand (6-20), Brown sand, hard (20-40), Brown sand (40-46), Gravel (46-52), Blue silt (52-61), Fine gravel, coarse sand & wood (61-82), Black sand, some water (82-85), Brown clay (85-95), Blue clay (95-115), Black rock (115-155), Brown rock (155-160), Black rock, some water (160-185), Brown rock & gravel (185-189)

Work started 10/20 1960. Completed 11/1 1960

(13) PUMP: Manufacturer's Name Type: H.P.

Well Driller's Statement: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A. M. JANNSEN DRILLING CO. (Person, firm, or corporation) (Type or print) Address 21075 S. W. Tualatin Hwy., Aloha, Ore.

Driller's well number [Signed] Edward Jannsen (Well Driller) License No. 79 Date 11/1 1960