

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

WASH WATER WELL REPORT

RECEIVED

cd

STATE ENGINEER, SALEM, OREGON 97301  
within 30 days from the date  
of well completion.

012055

STATE OF OREGON  
(Please type or print)

DEC 3 1973

State Well No. 25/1W-27

STATE ENGINEER  
SALEM, OREGON

(Do not write above this line)

(1) OWNER:

Name DONALD M DRAKE CO.  
Address 11125 TUALITIN SHERWOOD HWY SE 1/4 SW 1/4 Section 27 T. 28 R. 1W W.M.  
1740 NW FLANDERS PTLD. 97209

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Cable  Dug  Driven  Jetted  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other

(5) CASING INSTALLED:

Threaded  Welded   
8" Diam. from 71 ft. to 334 ft. Gage 1350  
" Diam. from " ft. to " ft. Gage  
" Diam. from " ft. to " ft. Gage

(6) PERFORATIONS:

Perforated?  Yes  No.  
Type of perforator used  
Size of perforations in. by in.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from " ft. to " ft.  
Diam. Slot size Set from " ft. to " ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Driller  
Yield: 60 gal./min. with 290 ft. drawdown after 2 hrs.  
" " " " " "  
" " " " " "  
Bailer test gal./min. with " ft. drawdown after " hrs.  
Artesian flow N<sub>s</sub> g.p.m.  
Temperature of water 40 Depth artesian flow encountered " ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT  
Well sealed from land surface to 20 ft.  
Diameter of well bore to bottom of seal " in.  
Diameter of well bore below seal 8 in.  
Number of sacks of cement used in well seal 7 sacks  
Number of sacks of bentonite used in well seal " sacks  
Brand name of bentonite  
Number of pounds of bentonite per 100 gallons of water " lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs " Size: location " ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel: " ft.  
Gravel placed from " ft. to " ft.

(10) LOCATION OF WELL:

County Washington Driller's well number 470  
SE 1/4 SW 1/4 Section 27 T. 28 R. 1W W.M.  
Bearing and distance from section or subdivision corner

Trd Lot #100 100

(11) WATER LEVEL: Completed well.

Depth at which water was first found 360 ft.  
Static level 110 ft. below land surface. Date 10-21  
Artesian pressure " lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"  
Depth drilled 400 ft. Depth of completed well 400 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
CLAY BROWN SANDY	0	20	
SAND & GRAVEL	20	30	
CLAY BROWN	30	50	
CLAY BROWN SANDY	50	120	
CLAY BROWN	120	130	
CLAY YELLOW	130	156	
CLAY BROWN	156	170	
SILT BROWN	170	334	
BASALT	334	360	
BASALT DECOMPOSED	360	400	110'

Work started Nov-20 1973 Completed Nov-22 1973  
Date well drilling machine moved off of well Nov-22 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Donald Forman Date 10/22, 1973  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 231

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Swift Water Well Drilling, Inc  
(Person, firm or corporation) (Type or print)  
Address 421 SW 6th Ave  
[Signed] Joe Mc Knight  
(Water Well Contractor)  
Contractor's License No. 576 Date 11/22, 1973