

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED
JUL 23 1965
STATE ENGINEER

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT
(Please type or print)

WASH
012113

State Well No. 2/HW-30

State Permit No. _____

(1) OWNER: SALEM OREGON

Name Ray A Zittlemoyer
Address RT 4 Box 95
Shewood Ore

(2) LOCATION OF WELL:

County Washington Driller's well number _____
1/4 1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner
Sec 30 T2S R12W

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded

6" Diam. from 71 ft. to 410 ft. Gage 4
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No

Type of perforator used _____
Size of perforations in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 70 ft. Was a packer used? no
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 45 ft. below land surface Date 7/15/65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
Bailer test 42 gal./min. with 35 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m. Date _____

Temperature of water 54 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 6

Depth drilled 470 ft. Depth of completed well 470 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	4
Brown clay	4	32
Brown silt	32	95
Blue clay lumps	95	125
Blue clay	125	240
Brown clay	240	270
Multi colored clay	270	285
Brown clay	285	405
Broken Rock	405	410
Ultramic Rock	410	470

Work started 7/6/65 19 65 Completed 7/15/65 19
Date well drilling machine moved off of well 7/15/65 19

(13) PUMP:

Manufacturer's Name Jacuzzi
Type: Sub H.P. 3

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME # Arrow Drilling & Supplies
(Person, firm or corporation) (Type or print)

Address 729 N. Main memberg

Drilling Machine Operator's License No. 82

[Signed] Paul M. Huffman
(Water Well Contractor)

Contractor's License No. 117 Date 7/17/65, 19