NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WASH 012141

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)
G 5429

RECEIVED FEB 26 1968 STATE ENGINEER SALEM, OREGON

State Well No. 2/1w-31bb
State Permit No. well #1

(1) OWNER:
Name Herb Elwert
Address Rt 3 Box 257 Sherwood ore

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from +8 ft. to 53 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 68 ft. below land surface Date 2/8/68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 30 gal./min. with 180 ft. drawdown after 1½ hrs.
Artesian flow g.p.m. Date
Temperature of water 53 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:
Well seal—Material used Bentonite
Depth of seal 51 ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County Washington Driller's well number
¼ ¼ Section T. R. W.M.
Bearing and distance from section or subdivision corner
Sec 31 T2S R1W

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 298 ft. Depth of completed well 298 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	3	
Brown Clay	3	27	
Decompose rock	27	47	
Med Basalt	47	85	
Hard "	85	124	
Weathered "	124	155	
Med "	155	185	
Pourri Red Rock	185	195	
Med Basalt	195	220	
Pourri Basalt "Water"	220	227	62
Med "	227	245	
Hard "	245	284	
Black Basalt	284	298	68

Work started 1-19 1968 Completed 2-6 1968
Date well drilling machine moved off of well 2-6 1968

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Wilbur J. Fuller (Drilling Machine Operator) Date , 19
Drilling Machine Operator's License No. 510

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Arrow Drilling & Supplies (Person, firm or corporation) (Type or print)
Address 729 N Main Newberg ore
[Signed] Harlan M. Hoffman (Water Well Contractor)
Contractor's License No. 117 Date 2/10, 1968

(USE ADDITIONAL SHEETS IF NECESSARY)