## The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion. SALEM, OSCINEER SALEM, OS

012143 State Well No. State Permit No.

of well completion. SALEM, ORESON  (1) OWNER:	C3 5429 Well #2
(1) OWNER:	(11) LOCATION OF WELL:
Name Harrharit Wlwart	County 70 ghir at gar Driller's well number 128
Address Rt. 2 Roy 257 Sharwaga, Oregon	14 S.T 14 Section 36 T. 25 R. 21 W.M.
	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	2)
New Well Deepening Reconditioning Abandon	4 - 2 2 2 2
If abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing
Cable   Jetted   Domestic   Industrial   Municipal   Dug   Bored   Irrigation   Test Well   Other	Depth drilled 280 ft. Depth of completed well 200 ft.
CASING INSTALLED: Threaded   Welded   C   Gage   C   Threaded   Welded   C   C   C   C   C   C   C   C   C	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.  MATERIAL From To SWL
" Diam. fromft. Gage	Red seil 0 14
The property of the property o	7:1 shale 14 22
PERFORATIONS: Perforated? ☑ Yes □ No.	Brow clay 22 39
Type of perforator used Teroli	Seft brews reck 38 57
Size of perforations 1/8 in. by 3 in.	Hard Basalt 57 102
perforations from 105 ft. to 115 ft.	Red shale 102 106 -
perforations from ft. to ft.	Medium basalt 106 113
perforations fromft. toft.	Rrewa shale 113 119
perforations from ft. to ft.	Hard basalt 119 162
perforations from ft. to ft.	Seft red rack 182 170
(7) SCREENS: Well screen installed? ☐ Yes ☐ No	Medium basalt 170 229
Manufacturer's Name	Hard basalt 229 264
Type Model No.	Soft black reck 264 280
Diam Slot size Set from ft. to ft.	Y Y
Diam. Slot size Set from ft. to ft.	
(8) WATER LEVEL: Completed well.	
Static level 43 ft. below land surface Date 3/18/70	
sian pressure lbs. per square inch Date	72 - 7
(9) WELL TESTS: Drawdown is amount water level is	AND ADMINISTRATION OF THE PARTY
lowered below static fever	
Was a pump test made? ☐ Yes ☐ Wo If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	
" " "	Date well drilling machine moved off of well 8/28/70 19
n n	Drilling Machine Operator's Certification:
Bailer test 30 gal./min. with 130 ft. drawdown after 2 hrs.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best
Artesian flow g.p.m. Date	knowledge and belief.
Temperature of water Was a chemical analysis made?   Yes No	[Signed] Lid Library Date 9/15, 1970
(10) CONSTRUCTION:	000
Well seal-Material used Coment	Drilling Machine Operator's License No. 200
Depth of seal 40	Water Well Contractor's Certification:
Diameter of well bore to bottom of seal10in.	This well was drilled under my jurisdiction and this report is
Were any loose strata cemented off?   Yes   No Depth	true to the best of my knowledge and belief.
Was a drive shoe used? ☐ Yes ☐ No	NAME Ted Schueler Well Drilling (Person, firm or corporation) (Type of Print)
Did any strata contain unusable water? 🔲 Yes 🗓 No	
Type of water? depth of strata	Address Rt.3 Box 687 Dundee, Oregon
Method of sealing strata off	[Signed] Theodore Whitely
Was well gravel packed? TYes No Size of gravel: 3/8	(Water Well Contractor)
Gravel placed from 40 ft. to 123 ft.	Contractor's License No. 18 4 Date 9/15 1970