

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT WASH
 OCT 13 1969 STATE OF OREGON 012166

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion

STATE OF OREGON

(Please type or print)

Do not write above this line

State Well No. 2/1W-34

State Permit No. _____

STATE ENGINEER
 SALEM, OREGON

(1) OWNER:

Name Lee Thompson
 Address Road 2 - Sherwood Ore.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

" Diam. from NONE ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No

Type of perforator used _____

Size of perforations in. by in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level _____ ft. below land surface Date _____
 Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
 _____: 106 gal./min. with 370 ft. drawdown after 2 hrs.
 _____: 82 " " 170 " " 1 "
 _____: 60 " " 110 " " 1 "

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water 54 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Seal not disturbed
 Depth of seal _____ ft.
 Diameter of well bore to bottom of seal _____ in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Washington Driller's well number 1969-47
 1/4 Section 34 T. 25 R. 1W W.M.
 Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 337 ft. Depth of completed well 579 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Basalt black Hard	242	260	53'
Basalt broken	260	262	
" Hard	262	360	
" Broken	360	378	70'
" Hard	378	460	
" Soft	460	478	
" Hard	478	483	
" Soft	483	484	
" Hard	484	509	
" soft Red	509	513	
" Hard black	513	516	
" Porous	516	519	
" Hard	519	571	
" Porous	571	579	
" Decomposed	579	580	
" Hard	580	594	
" Porous	594	598	110
" Hard	598	639	110

Work started Aug 12 1969 Completed Sept 10 1969

Date well drilling machine moved off of well Sept 10 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Marvin A. Skyles Date Oct 10, 1969
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 224

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Skyles Drilling & Supply, Inc.
 (Person, firm or corporation) (Type or print)

Address Shelburne Oregon

[Signed] George H. Skyles
 (Water Well Contractor)

Contractor's License No. 59 Date Oct 10, 1969