

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM 10, OREGON
 within 30 days from the date
 of well completion.

WATER WELL REPORT

WASH
 012186

STATE OF OREGON
 (Please type or print)
 FEB 27 1963

State Well No. 2/W-34 R
 State Permit No. _____

(1) OWNER:

Name Lee Thompson
 Address RT. 1
Sherwood Ore.

(2) LOCATION OF WELL:

County Clatsop Wash Driller's well number _____
SE 1/4 SE 1/4 Section 34 T. 2S R. 1W W.M.
 Bearing and distance from section or subdivision corner _____

TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8 " Diam. from 0 ft. to 88' 7" ft. Gage .250
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used _____
 Size of perforations in. by in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
 Manufacturer's Name _____
 Model No. _____
 Slot size Set from _____ ft. to _____ ft.
 Diam. Slot size Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement
 Depth of seal 88' ft. Was a packer used? no
 Diameter of well bore to bottom of seal 8 1/2 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 51 ft. below land surface Date 2/11/63
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 " " " " " "
 " " " " " "
 Bailer test 50 gal./min. with 14 ft. drawdown after 2 hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8 1/2 to 200'
 Depth drilled 370 ft. Depth of completed well 370 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	1
Yellow clay sandy	1	23
Brown sandy clay	23	29
Red clay	29	33
Brown sandy clay	33	62
Brown decomposed rock	62	88
Brown honeycomb rock (water)	88	93
Black Rock hard	93	103
Grey decomposed rock	103	120
Grey rock Hard	120	143
Grey Honeycomb rock	143	148
Brown rock	148	189
Grey conglomerate	189	263
Grey rock	263	283
Soft black rock	283	284
Brown decomposed rock	284	294
Soft black rock (water)	294	301
Brown conglomerate	301	316
Grey rock	316	357
Soft black rock (water)	357	368
Green conglomerate	368	370

Work started 12/17/62 19 _____ Completed 2/11/63 19 _____
 Date well drilling machine moved off of well 2/11/63 19 _____

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Steinman Bros. (Person, firm or corporation) (Type or print)

Address Milwaukie, Ore

Drilling Machine Operator's License No. 67

[Signed] Steinman Bros. (Water Well Contractor)

Contractor's License No. 1 Date 2/18/63, 19 _____