

G4970

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

SEP 30 1966 WATER WELL REPORT

WASH

STATE ENGINEER, SALEM, OREGON 97310

ENGINEER STATE OF OREGON (Please type or print)

012203

State Well No. 2/100-34 J

State Permit No.

(1) OWNER:

Name Lee Thompson
Address RT 2
Sturwood Ore

(2) LOCATION OF WELL:

County Washington
Driller's well number 41-66
NE 1/4 Section 34 T. 2S R. 1W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []
Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 73 ft. Gage 250
Welded [X]

(7) PERFORATIONS:

Perforated? [] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal cement
Depth of seal 73 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? [] Yes [X] No
Was a drive shoe used? [] Yes [X] No
Was well gravel packed? [] Yes [X] No
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 93 ft. below land surface Date 9/21/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [X] No
Yield: gal./min. with ft. drawdown after hrs.
Bailer test 35 gal./min. with 22 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 52 Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 347 ft. Depth of completed well 347 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include Top soil, Brown decomposed rock, Grey Rock, Red soft Rock, Grey soft Rock, Brown Rock, Grey Rock Hard, Brown seamy Rock, Grey Rock Hard, Grey Broken Rock (water), greenish grey rock, grey rock Hard, Grey Broken Rock (water), Black Rock, Grey rock hard.

Work started Aug 9 1966 Completed Sept 20 1966
Date well drilling machine moved off of well Sept 23 1966

(13) PUMP:

Manufacturer's Name
Type: H.P.
Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Steinman Bros
Address Milwaukie Ore
Drilling Machine Operator's License No. 67
[Signed] Steinman Bros (Water Well Contractor)
Contractor's License No. / Date Sept 28, 1966