NOTICE TO WATER WELL STATE OF THE OFFICIAL AND STATE OF THE OFFICE AUG 14 1972

TER WELL REPORTWASH

state engineer, salemore on 12474

state engineer, salemore on 12474

within 30 days from the date of well completion. SALEM ORLSONO not write above this line)

G-6/86

State Permit No.

(1) OWNER:	(10) LOCATION OF WELL:
Name Robert Wolff	County Washington Driller's well number
Address 9120 S. W. Scholls Ferry Road	14 14 Section 8 T. 2 S R. 2 W. W.M.
Tigard, Oregon 97223	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well 🗵 Deepening 🗌 Reconditioning 🗎 Abandon 🗎	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 294 ft.
Rotary Driven Domestic Industrial Municipal	Static level 90 ft. below land surface. Date 7/25/72
Cable Jetted	Artesian pressure lbs. per square inch. Date
5) CASING INSTALLED: Threaded Welded X 8 " Diam. from 0 ft. to 260 ft. Gage 250 64 " Diam. from 0 ft. to 290 ft. Gage 188 188	(12) WELL LOG: Diameter of well below casing 811 Depth drilled 3214 ft. Depth of completed well 3214 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
	Top soil 0 2
Size of perforations in. by in. perforations from ft. to ft.	Hard pan 2 3
perforations from ft. to ft.	Sandy clay 3 18
perforations from ft. to ft.	Brown sand 18 64
perforations from	Blue sand (fine) 64 97
(7) SCREENS: Well screen installed? ☐ Yes ▼ No	Blue clay 97 108
Manufacturer's Name	Blue sand 108 114
Type Model No	Blue clay 1114 151
Diam. Slot size Set from ft. to ft.	Brown clay 151 205
Diam Slot size Set from ft. to ft.	Innerbed red clay 205 207 Brown clay 207 242
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Brown clay 207 242 Decomposed & clay 242 253
	Hard gray rock 253 262
Was a pump test made? ☐ Yes ☒ No If yes, by whom?	Broken gray rock 262 280
Yield: gal./min. with ft. drawdown after hrs.	Hard gray rock (280 294
	Purple perforated rock 294 309 35 gpm
" " " " " " " " " " " " " " " " " " "	Hard gray rock 309 324
Bailer test 35 gal./min. with 225ft. drawdown after 2 hrs.	
Artesian flow g.p.m.	
emperature of water Depth artesian flow encountered ft.	Work started 7/6/72 19 Completed 7/25/72 19
(9) CONSTRUCTION:	Date well drilling machine moved off of well 7/25/72 19
Well seal—Material usedCement	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of seal 15-5/8 in.	best knowledge and belief.
Diameter of well bore below seal	[Signed] Corilling Machine Operator)
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No235
Number of sacks of bentonite used in well seal sacks	
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is
of water	true to the best of my knowledge and belief.
Was a drive shoe used? ☐ Yes 🖾 No Plugs Size: location ft.	Name A. M. Jannsen Drilling Co.
Did any strata contain unusable water? Yes No	(Person, firm or corporation) (Type or print) Address 21075 8. Tualatin Valley Hwy, Aloha,0
Type of water? depth of strata	Address 210735 10414 ALIS IIW ALIS IIW
Method of sealing strata off	[Signed] Galward M. Clemen
Was well gravel packed? ☐ Yes 🖺 No Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No79 Date _8/2/72, 19