NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

WASH

WATER WELL REPORT
STATE OF OREGON

(Please type or print)

012478

(Do not write above this line)

RECEIVED
MAY 17 1978
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 2S/2W-8ba

State Permit No.

(1) OWNER:
Name Hettie O'Dell
Address R#2, Box 146, Hillsboro, Oregon, 97123

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(5) CASING INSTALLED: Threaded [ ] Welded [X]
6" Diam. from 0 ft. to 266 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? [ ] Yes [X] No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 12 gal./min. with 120 ft. drawdown after 1½ hrs.
Artesian flow g.p.m.
Temperature of water 51 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement Grout
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 7 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? [X] Yes [ ] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Washington Driller's well number 243
NE ¼ NW ¼ Section 8 T. 2S R. 2W W.M.
Bearing and distance from section or subdivision corner
2065' East and 362' South of NW Corner Sec 8

(11) WATER LEVEL: Completed well.
Depth at which water was first found 308 ft.
Static level 37 ft. below land surface. Date 4/25/78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 315 ft. Depth of completed well 315 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Clay - brown	0'	48'	
Clay - dark gray	48	62	
Clay - blue with sand	62	108	
Clay - blue	108	135	
Clay - brown	135	146	
Clay - red	146	158	
Clay - brown	158	242	
Sandstone - gray	242	268	
Gray Rock with Clay	268	315	37'

Work started 4/12 1978 Completed 4/25 1978
Date well drilling machine moved off of well 5/16 1978

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Jack Barson (Drilling Machine Operator) Date 5/16, 1978
Drilling Machine Operator's License No. 165

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Jack Barson (Person, firm or corporation) (Type or print)
Address 16425 S.W. Hart, Beaverton, Oregon
[Signed] Jack Barson (Water Well Contractor)
Contractor's License No. 59 Date 5/16, 1978

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119