

RECEIVED  
NOV - 1 1962

WASH

012676

Keep last copy for your records return first 3. Thank you  
2/2W-16M

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT

State Well No.

STATE OF OREGON G-7278

State Permit No. G-6741

(1) OWNER: Name Milton M. Wolborn  
Address 1515 S. E. 122nd Portland Oregon

(2) LOCATION OF WELL: County WASH Owner's number, if any—  
N.W. 1/4 SW 1/4 Section 16 T. 25 R. 2W W.M.  
Bearing and distance from section or subdivision corner  
N 53° 3' W 210'-0"  
FROM MOST WESTERLY CORNER OF WOLBORN FARM.

(3) TYPE OF WORK (check): New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check): Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
(5) TYPE OF WELL: Rotary  Cable  Dug  Driven  Jetted  Bored

(6) CASING INSTALLED: Threaded  Welded   
6" Diam. from 0 ft. to 32 ft. Gage 17 LBS  
STEEL from 3110 ft. to PER FT.  
Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS: Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
SIZE of perforations in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS: Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION: Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Was a surface seal provided?  Yes  No To what depth? \_\_\_\_\_ ft.  
Material used in seal— DRILLING MUD + CEMENT.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS: Static level 107 ft. below land surface Date 9/17/62  
Artesian Pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Log Accepted by: M. M. Wolborn  
[Signed] \_\_\_\_\_ Date Sept 24, 1962  
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? \_\_\_\_\_

Yield:	gal./min. with	ft. drawdown after	hrs.
<u>"30 GPM</u>	<u>"60' DD</u>	<u>"6</u>	<u>"</u>
<u>"</u>	<u>"</u>	<u>"</u>	<u>"</u>
Bailer test	gal./min. with	ft. drawdown after	hrs.
Artesian flow	g.p.m.	Date	
Temperature of water	Was a chemical analysis made?	<input type="checkbox"/> Yes <input type="checkbox"/> No	

(12) WELL LOG: Diameter of well 6 inches.  
Depth drilled 190 ft. Depth of completed well 190 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>SOIL</u>	<u>0</u>	<u>2</u>
<u>BROWN CLAY</u>	<u>2</u>	<u>32</u>
<u>Rock GREY MED. HD</u>	<u>32</u>	<u>105</u>
<u>DIED Rock</u>	<u>105</u>	<u>110</u>
<u>CEMENTED Rock WITH</u>		
<u>1 YARD OF CEMENT +</u>		
<u>SAND 2 TIMES.</u>	<u>130</u>	<u>96</u>
<u>Rock MED HD.</u>	<u>110</u>	<u>170</u>
<u>Rock SOFT</u>	<u>170</u>	<u>180</u>
<u>Rock MED HD</u>	<u>180</u>	<u>190</u>
<u>WATER</u>	<u>12 GPM</u>	<u>110 115</u>
<u>WATER</u>	<u>18 " " "</u>	<u>170 180</u>

Work started 8/23 1962 Completed 9/17 1962

(13) PUMP: Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Well Driller's Statement: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME PAUL E ROSS  
(Person, firm, or corporation) (Type or print)  
Address 2040 SW 192 ALBANY ORE.  
Driller's well number \_\_\_\_\_  
[Signed] Paul E Ross  
(Well Driller)  
License No. 94 Date 9/17, 1962