

RECEIVED
MAY 19 1959

WASH
012677

GR 2017 OBSERVATION WELL

2/2W - 16N(2)

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No.

State Permit No.

(1) OWNER:

Name Mountainside Cemetary Association
Address c/o Geo., Wendland, Secretary
Route #1 - Newberg, Oregon

(2) LOCATION OF WELL: Reg. No. GR 2017

County Washington Owner's number, if any—
NEWSW 1/4 SW 1/4 Section 16 T. 25 R. 2W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): Reaming from 6" to 8"

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

8 " Diam. from 0 ft. to 54 ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used

SIZE of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name
Type Model No.
..... Slot size Set from ft. to ft.
..... Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 54 ft.
Material used in seal— casing

Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 27 ft. below land surface Date 5-4-59
Artesian pressure lbs. per square inch Date

Log Accepted by:

Mountainside Cemetary Date May 16, 1959
[Signed] (Owner)

By George Wendland Sec.

(USE ADDITIONAL SHEETS IF NECESSARY)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? -
Yield: gal./min. with ft. drawdown after hrs.
" " " " " " "
" " " " " " "
" " " " " " "
Bailer test NO gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8 inches.

Depth drilled 229 ft. Depth of completed well 229 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
clay	0	54
hard & soft layers rock	54	85
black rock	85	105
hard rock creviced	105	127
IX hard & soft layers grey rock	127	229

Work started 4-16-59 19 . Completed 5-4-59 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A. M. Janssen Drilling Company
(Person, firm, or corporation) (Type or print)

Address 21075 S. W. Tualatin Hiway - Aloha, Oregon

Driller's well number

[Signed] Edward M. Janssen
Edward M. Janssen Partner

License No. 79 Date 5-5-59, 19.....