WATER WELL REPORT STATE OF OREGON

JUL 201983

RECEIVED

012932 WATER RESOURCES I

WATER RESOURCES DERILE Permit No.

(1) OWNER:	(10) LOCATION OF WELL:	-
Name Charlie Huckins	County Washington Driller's well number 316	
Address 12200 S.W. 116th		O 17
City Tigard, Oregon 97223 State	Tax Lot # Lot Blk	R. Z-W W.M. Subdivision
(2) TYPE OF WORK (check):	Address at well location: Rt. 4, Box 299 C	
New Well	Sherwood, OR 97140	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
	Depth at which water was first found 120 ft.	
	Static level 80 ft. below l	and surface. Date 7/11/83
Rotary Air	Artesian pressure lbs. per square inch. Date	
☐ Bored ☐ Thermal: Withdrawal ☐ Reinjection ☐	(12) WELL LOG: Diameter of well below	ressing 811
(5) CASING INSTALLED: Steel X Plastic	Depth drilled 182 ft. Depth of completed well 182 ft.	
(5) CASING INSTALLED: Steel X Plastic Threaded Welded X	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level	
6		
"Diam. from ft. to ft. Gauge	and indicate principal water-bearing strata.	position of Static Water Level
LINER INSTALLED:	MATERIAL	From To SWL
ft. Gauge	Top Soil	-
(A) DEDECT ATTONYO	Brown Clay	0 3
(6) PERFORATIONS: Perforated? ☐ Yes 🕱 No	Soft Decomposed Basalt	25 60
Type of perforator used Size of perforations in by in.	Med. Hard Brown Basalt	60 110
	Hard Gray Basalt	110 125
perforations from ft. to ft.	Hard Blk. & Brwn. Becompo	
perforations from	Basalt Basalt	125 145
perforations from	Hard Blk. & Brwn. Broken	123 143
(7) SCREENS: Well screen installed? ☐ Yes X No	Basalt	145 155
Manufacturer's Name	Hard Gray Basalt	155 182
Type Model No.	- June June June June June June June June	133 102
Diam. Slot Size Set from ft. to ft.	<u> </u>	
<u>Diam.</u> Slot Size Set from ft. to ft.		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		
a pump test made? Yes No If yes, by whom?		
Yield: gal./min. with ft. drawdown after hrs.		
11 " " "	and the second s	-
Air test 150 gal./min. with drill stem at 180 ft. 1 hrs.		
Bailer test gal./min. with ft. drawdown after hrs.		
sian flow g.p.m.	and the same of th	
Temperature of water 50 Depth artesian flow encountered ft.	Work started 7/7/83 19 Complete	ed 7/11/83 19
(9) CONSTRUCTION: Special standards: Yes \(\sigma \) NoX	Date well drilling machine moved off of well 7/11/83 19	
Well seal—Material used Cement	(unbonded) Water Well Constructor Certification (if applicable):	
Well sealed from land surface toft_	This well was constructed under my direct supervision. Materials used	
Diameter of well bore to bottom of seal	and information reported above are true to my b	est knowledge and belief.
Diameter of well bore below sealin.	[Signed] Louis Solomo	Date 1/15, 19.88
Number of sacks of cement used in well seal	Bonded Water Well Constructor Certificati	ion
How was cement grout placed? Punped	Bond <u>U975081</u> Issued by: United Pacific Ins. Co	
and the state of t	(number) Sur	rety Company Name
The state of the s	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
Was pump installed?	Name Aroow Drilling	
Was a drive shoe used? ☐ Yes X No Plugs	(Type or print) Address 729 N. Main Newborn OP 97133	
Type of Water? depth of strata	Address 729 N. Main, Newberg, OR 97132	
Method of sealing strata off	Signed Louis	
Was well gravel packed? ☐ Yes No Size of gravel:	Water Well Construc	tor
Gravel placed from	Date	, 19.
A SAUTHER CONTRACTOR AND A SAUTHER CONTRACTOR	<u> </u>	· · · · · · · · · · · · · · · · · · ·